



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/67

Dated: 29/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya No. 1 located at Sarojini Nagar, New Delhi-110023 (School ID: 1719029), comprised of ground plus one upper floor, owned/occupied by Director of Education, Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2021/56 dated 21/01/2021. The school premise was re-inspected by the officer concerned of this department on 19/01/2024 in the presence of Mrs. Vijaita Yadav (Lecturer) and observed that said school building have deemed complied with the fire prevention and fire safety requirement in accordance with the circular issued by Director of Education dated 01/03/2011 and that the school building is fit for occupancy class **Group-B** (Educational) with effect from 29/01/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/01/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
OIC SF

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya No. 1 at Sarojini Nagar, New Delhi-110023
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Kanya Vidyalaya, Sarojini Nagar, New Delhi-110023 (School ID: 1719029)		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground plus one upper floor only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/56 dt.21/01/2021		
6.	Fire Safety directives Letter No.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7.	Date of inspection	19/01/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Mrs. Vijaita Yadav (Lecturer)		
10.	Year of Construction	1962		
11.	Applicant's letter No	Email dated 28/12/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required NA NA	9m NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Required	02 Nos	MR
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.5m/0.75m NA	1.60m (each) NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width of Corridor	NA	1.5m	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	14 Nos ABC / CO ₂ ISI Marked	40 Nos ABC & CO ₂ Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/2021/56 dated 21/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
21/01/21
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

Mull
24/1/21

CFD
22/01/2021
Director
27/1/21
AD (SJ)

Sir, F.T letter is put up for your signature pl

Director
25/1/21
AD

Santosh Kumar
25.01.21