

e38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/SZ/2024/36

Dated: 02/02/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant (A unit of sapphire foods), UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058, building is comprised of basement, stilt, upper ground floor plus two upper floors but the restaurant is running at upper ground floor only, was issued FSC by this department vide letter F6/DFS/MS/EH/2020/SZ/10 dated 07.01.2021 owned/occupied by M/s KFC Restaurant (A unit of sapphire foods) was re-inspected by the officers concerned of this department on 31.01.2024 in the presence of Hari Bhandari (Restaurant Manager) and the building/premises is fit for occupancy class Assembly (Restaurant) at UpperGround floor only with effect from 02/02/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 02/02/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
h

Online Application ID 2024010300099 dated 18/01/2024

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N/16

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant (A unit of sapphire foods), UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058
2. Building comprised of : Basement, stilt ,upper ground.+2 upper floors but restaurant running at upper ground only
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2020/SZ/10
- 6.
7. dated 07.01.2021
8. Fire Safety directives letter No : N/A
9. Date of inspection : 31.01.2024
10. Name of Inspecting Officers : Vedpal Chhikara, DO (SW) & R.K. Yadav, A.D.O. (JKP)
11. Name and designation of officers
From the building side : Hari Bhandari (Restaurant Manager)
12. Year of Construction : 2009
13. Applicant's letter No. : ID No.2024010300099 dated 18/01/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 4.5 mtrs N/A	12 mtrs 5.3 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 no.'s	02 no.'s (stilt to upper GF)	MR (restaurant at UGF only)
	<ul style="list-style-type: none"> • Upper Floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Basements 			
	b. Width of staircases	1.5 m	1.90 & .90 m	MR being old bldg.
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	One	N/A
		N/A	Opening in hall	N/A
	e. Width of Corridor	02 mtrs	2.0 & 1.20 m	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	04 No.'s ABC/CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR

15

1

N/17

6.	First-Aid Hose Reels	(Restaurant is at UGF only)		
	<ul style="list-style-type: none"> Total numbers on ground floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Required N/A Required Required	Provided UG Floor N/A Provided At exit	MR MR N/A MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System	(Restaurant is at UGF only)		
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	N/A MR N/A
11.	Internal Hydrants	(Restaurant is at UGF only)		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 900 LPM 40 mtrs Required Required	N/A Provided Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A Required N/A 10000 ltrs	N/A N/A Provided N/A Provided	N/A N/A MR N/A MR
15.	Exit Signage.	Required	Provided	MR

10

N/18

16.	Provision of Lifts.	(Restaurant is at UGF only)		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2020/SZ/10 dated 07.01.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

Vedpal Chhikara
 Signature of the inspecting officer
 Name- Vedpal Chhikara
 Designation- DO (SW)

CFO (SZ)
[Signature]
 1/21/2024

[Signature]
 Director
 11/21/24

[Signature]
 ADO/JKP

FT letter is put up for sign of
[Signature] 2/2/24
 DO (S.W)
 DIRECTOR / DFS / JKP
[Signature] 2/17/24
[Signature]
 Uploaded
 02/10/23