



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/SZ/2024/ 74

Dated: 06/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Nehru Homeopathic Medical College and Hospital Located at B- Block, Defence Colony, New Delhi-110024, having three Blocks [Main ward & OPD Block(interconnected single block) comprised of Ground Plus three upper floors, Admin Block comprised Ground plus three upper floors & Teaching Block comprised Ground plus two upper floors, owned/occupied by Govt. of NCT of Delhi was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/Hospital/2021/SZ/54 dated 22/01/2021. The premises was re-inspected by the officers concerned of this department on 27/01/2024 in the presence of Sh. Dharmender (Operator) and observed that all the fire prevention and fire safety arrangement provided in the premises found in good work condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "Institutional" (Group-'C') with effect from 06/02/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 06/02/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. A.E. Electrical, PWD, Health Wing, Electric Division, South-West, New Delhi.
2. Medical Superintendent, Nehru Homeopathic Medical College and Hospital Located at B-Block, Defence Colony, New Delhi-110024.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc, may be got verified from concerned authorities.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' (Form No. (1) of 2011) along with a copy of this Certificate six months prior to its expiry.

N-23

## INSPECTION REPORT

1.	Name & address of the building	Nehru Homeopathic Medical College and Hospital Located at B- Block, Defence Colony, New Delhi-110024		
2.	Type of Occupancy	Institutional building "C" (Hospital)		
3.	Building Comprised of	Three Blocks. Main ward & OPD Block= Ground Plus three upper floors, Admin Block= Ground plus three upper floors & Teaching Block= Ground plus two upper floors. Main block and admin Blocks are interconnected at ground floor and first floor only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/Hospital/2021/SZ/54 dated 22/01/2021		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	27/01/2024		
8.	Name of the Inspecting Officer	Manoj Kumar Sharma (DO/SD) & Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Sh. Dharmender (Operator)		
10.	Year of Construction	1969 & Teaching Block 2010.		
11.	Applicant's letter No	Letter No. 24(10)/AE(E)-III/PWD HMED SW/2023-2024/12 dated 15/01/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	12 m	MR
	• Gate width	5m	6 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Main Block= 2, Admn Block=1 & Teaching BLK=1	Main Block= 1.25m, 1.15m & 2m , Admn Block=1.14m & Teaching BLK=1.8m	MR(Old Case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Main & Admn Block= 1.37m (each) & Teaching BLK=1.5m	1 <sup>st</sup> Block- 1.5m & 1.40m 2 <sup>nd</sup> Block- 1.20m & 1.80m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 (each block)	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size (Classroom)	1m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA Required	NA Natural ventilation	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	34 Nos ABC/ WCO <sub>2</sub> /CO <sub>2</sub> ISI marked	89 Nos ABC & CO <sub>2</sub> Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	05 Nos 30m 5mm	Provided 30m 5mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat Ground Floor NA NA All areas	Provided Ground floor NA NA All areas	MR MR NA NA MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150mm 5 5	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	12 Nos 12 Nos	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul> </li> </ul>	1620 LPM 60MH 1 180LPM 60MH 1620LPM 60MH Required Required NA NA NA NA	1620 LPM 60MH 1 180LPM 60MH 1620LPM 60MH Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR NA NA NA NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	50,000 Ltr. Required Required Required 10,000 Ltr.	1,00,000 Ltr. Provided Provided Provided Provided	MR MR MR MR MR

180

2

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC & CO <sub>2</sub>	Provided in electrical panels	MR

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/Hospital/2023/SZ/1629 dated 07/08/2023 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/Hospital/2021/SZ/54 dated 22/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Manoj*  
 01/01/24  
 Signature of the Inspecting Officer  
 Name: Manoj Kumar Sharma  
 Designation: DO (SD)

*Santosh Kumar*  
 31.01.24  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (SJ)

CFO/HO  
*Manoj*  
 21/01/2024  
 Director  
*Manoj*  
 21/01/24  
 ADO/SJ

Sir, F.T letter is pending for your signature pl.  
*Manoj*  
 05/02/24