

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/42

Dated : 07/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s G.T Road Restaurant (A unit of Capital Foodworks LLP) located at M-39, Ground Floor & Mezzanine Floor, Outer Circle, Connaught Place, New Delhi, comprises of Ground, mezzanine + 02 upper floors occupied by M/s G.T Road Restaurant (A unit of Capital Foodworks LLP) was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/2021/22 dated 29/01/21. Now, the premises was re-inspected by the officer concerned of this department on 02/02/24 in the presence of Mr. Prakash Chandra, Manager and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building Group D Restaurant at Ground Floor & Mezzanine floor only and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, mentioned below.

Issued 07/02/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Id No. 2024011800583 dated 28/01/24.
2. The Manager,  
M/s G.T Road Restaurant (A unit of Capital Foodworks LLP), located at M-39, Ground Floor & Mezzanine Floor, Outer Circle, Connaught Place, New Delhi.

**Condition for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Inflammable material, if any for interior decoration, shall strictly be prohibited.

## INSPECTION REPORT

1. Name & address of the building M/s G.T Road Restaurant  
(A unit of Capital Foodworks LLP)  
M-39, Ground Floor & Mezzanine Floor,  
Outer Circle, Connaught Place,  
New Delhi - 110001
2. Type of occupancy:- Assembly -D (Gr. + Mezzanine Floor )
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2021/22 dated 29/01/21
5. Fire safety directives No.- N/A
6. Date of inspection:- 02/02/24.
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer  
From the building side:- Sh. Prakash Chandra  
Heritage
9. Year of construction:-
10. Applicant's letter No:- Id No. 2024011800583 dated 28/01/24.

Old Case

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement/ Existing fire safety arrangements | Provided at site                   | Remarks MR/NMR |
|-----------|---|--|------------------------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |  |                                    |                |
|           | 1) Road width   | 06 mtr.  | 9 mtr.                             | MR             |
|           | 2) Gate width   | N/A  | Directly accessible from main road | MR             |
|           | 3) Width of internal road                                   | N/A  | N/A                                | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |  |                                    |                |
|           | <b>A. Number of staircases</b>                              |  |                                    |                |
|           | 1. Upper floors (Mezz. Floor)                               | 02 No.   | 03 No.                             | MR             |
|           | 2. Basements  | N/A  | N/A                                | N/A            |
|           | <b>B. Width of staircase</b>                                |  |                                    |                |
|           | 1. Upper floors (Mezz. Floor)                               | 1.5 & 0.80 mtr                                 | 1.5 & 1.18 mtr & 85cm.             | MR             |
|           | 2. Basements  | N/A  | N/A                                | N/A            |
|           | <b>C. Protection of exits</b>                               |  |                                    |                |
|           | 1. Fire check door  | N/A  | N/A                                | N/A            |
|           | 2. Pressurization   | N/A  | N/A                                | N/A            |
|           | <b>D. No. of continuous staircase to terrace</b>            |  |                                    |                |
|           |   | N/A  | 01                                 | N/A            |
|           | <b>E. Width of corridor</b>                                 |  |                                    |                |
|           |   | N/A  | N/A                                | N/A            |
|           | <b>F. Door size</b>   |  |                                    |                |
|           |   | 2mtr, 1.20mtr.                                 | 2mtr, 1.20mtr.                     | MR             |
| <b>3.</b> | <b>Compartmentation</b>                                     |  |                                    |                |
|           | 1) Fire check door  | N/A  | N/A                                | N/A            |
|           | 2) Sealing of electrical shafts                             | N/A  | N/A                                | N/A            |
|           | 3) Fire rating of shaft door                                | N/A  | N/A                                | N/A            |
|           | 4) Water curtain  | N/A  | N/A                                | N/A            |
|           | 5) Fire Dampers   | N/A  | N/A                                | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |  |                                    |                |
|           | 1) Basements  | N/A  | N/A                                | N/A            |
|           | 2) Upper floors   | 12 ACPH  | Natural                            | MR             |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |  |                                    |                |
|           | 1) Total numbers  | 10 Nos.  | 10 Nos.                            | MR             |
|           | 2) Types  | CO2 & ABC                                      | CO2 & ABC                          | MR             |

|            |   |            |          |     |
|------------|---|------------|----------|-----|
|            | 3) ISI marking  | ISI marked | Provided | MR  |
| <b>6.</b>  | <b>First-Aid Hose Reel</b>                            |            |          |     |
|            | 1) Total number on each floor                         | 01         | 02       | MR  |
|            | 2) Length of hose reel hose                           | 30 mtr.    | 30 mtr.  | MR  |
|            | 3) Nozzle diameter                                    | 05 mm      | 05 mm    | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |            |          |     |
|            | 1) Type of detectors                                  | N/A        | N/A      | N/A |
|            | 2) Location of main panel                             | N/A        | N/A      | N/A |
|            | 3) Location of repeater panel                         | N/A        | N/A      | N/A |
|            | 4) Alternate source of power                          | N/A        | N/A      | N/A |
|            | 5) Hooter's Location                                  | N/A        | N/A      | N/A |
| <b>8.</b>  | <b>MOEFA</b>  | Required   | Provided | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | N/A        | N/A      | N/A |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |            |          |     |
|            | 1) Basement   | N/A        | N/A      | N/A |
|            | 2) Upper floors                                       | N/A        | Provided | N/A |
|            | 3) Sprinkler above false ceiling                      | N/A        | Provided | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |            |          |     |
|            | 1) Size of riser/down-comer                           | 100 mm     | 100 mm   | MR  |
|            | 2) Number of hydrants per floor                       | 01         | 02       | MR  |
|            | 3) Hose box   | 01         | 02       | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |            |          |     |
|            | 1) Total number of hydrants                           | N/A        | N/A      | N/A |
|            | 2) Hose box   | N/A        | N/A      | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |            |          |     |
|            | 1) Ground level                                       | N/A        | N/A      | N/A |
|            | a) Discharge of main pump                             | N/A        | N/A      | N/A |
|            | b) Head of main pump                                  | N/A        | N/A      | N/A |
|            | c) Number of main pump                                | N/A        | N/A      | N/A |
|            | d) Jockey pump out put                                | N/A        | N/A      | N/A |
|            | e) Jockey pump head                                   | N/A        | N/A      | N/A |
|            | f) Stand by pump output                               | N/A        | N/A      | N/A |
|            | g) Stand by pump head                                 | N/A        | N/A      | N/A |
|            | h) Auto starting/Manual stopping                      | N/A        | N/A      | N/A |
|            | 2) Terrace level                                      |            |          |     |
|            | a) Discharge of pump                                  | 450 LPM    | 450 LPM  | MR  |
|            | b) Head of pump                                       | 30 mtr.    | Provided | MR  |
|            | c) Power supply                                       | Required   | Provided | MR  |
|            | d) Auto starting of pump                              | Required   | Provided | MR  |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |            |          |     |

Red

W<sub>1</sub>

|     |  |             |               |     |
|-----|--|-------------|---------------|-----|
|     | 1) Under ground tank capacity  | N/A         | N/A           | N/A |
|     | a) Draw-off connection   | N/A         | N/A           | N/A |
|     | b) Fire service inlet  | N/A         | N/A           | N/A |
|     | c) Access to tank  | N/A         | N/A           | N/A |
|     | d) Over head tank capacity   | 10,000 ltr. | 10,000 ltr. / | MR  |
| 15. | Exit Signage.  | Required    | Provided      | MR  |
| 16. | Provision of Lifts.  |             |               |     |
|     | a) Pressurization of lift shaft  | N/A         | N/A           | N/A |
|     | b) Pressurization of lift lobby  | N/A         | N/A           | N/A |
|     | c) Communication in lift car   | N/A         | N/A           | N/A |
|     | d) Fireman's switch  | N/A         | N/A           | N/A |
|     | e) Lift signage  | N/A         | N/A           | MR  |
| 17. | Stand by Power Supply  | Required    | Provided      | MR  |
| 18. | Refuge Area  | N/A         | N/A           | N/A |
|     | Total area location  | N/A         | N/A           | N/A |
| 19. | Fire Control Room  | N/A         | N/A           | N/A |
|     | a) Detector system panel   | N/A         | N/A           | N/A |
|     | b) Flow switch panel   | N/A         | N/A           | N/A |
|     | c) PA system panel   | N/A         | N/A           | N/A |
|     | d) Battery backup  | N/A         | N/A           | N/A |
|     | e) Building floor plan   | N/A         | N/A           | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: |             |               | N/A |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2021/22 dated 29/01/21, and renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

*[Handwritten Signature]*

Name: - Sh. Rajinder Atwal  
Designation: - DO (CD)

*[Handwritten Signature]*  
Dy. C.F.O. (202)

C.F.O.

*[Handwritten Signature]*  
02/2/24

*[Handwritten Signature]*  
Director  
21/1/2024  
5/2/24