

88

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/EH/2024/ 37

Dated: .05./02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the My Bar Square, (A Unit of Sachi Hospitality Pvt. Ltd.) located at E-34, 35, 1<sup>st</sup> floor, Connaught Place, New Delhi in a building is comprised of Ground floor + 2 upper floor but restaurant is running at 1<sup>st</sup> floor only, was earlier granted FSC by this department vide letter F.6/DFS/MS/EH/2021/15 dated 18/01/2021. Now, the premises was re-inspected by the officers concerned of this department on 30/01/24 in the presence of Manager and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D –restaurant at first floor only** and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, mentioned below.

Issued ..05/02/2024...at New Delhi by.

  
(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.  
ID No. 2024011900633 dated 19.01.24.
3. The Manager, M/s My Bar Square, (A Unit of Sachi Hospitality Pvt. Ltd.) located at E-34- 35 1st floor, Connaught Place, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Inflammable material, if any for interior decoration, shall strictly be prohibited.

**INSPECTION REPORT**

1. Name & address of the building:- My Bar Square, (A Unit of Sachi Hospitality Pvt. Ltd.),E-34, 35 1<sup>st</sup> floor, Connaught Place, New Delhi.
2. Type of occupancy:- Group – D Assembly Building  
Ground + 2 upper floor (**Restaurant at 1<sup>st</sup> floor only**)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2021/15 dated 18/01/2021
5. Fire safety directives No.- N/A
6. Date of inspection:- 30/01/2024
7. Name of the inspecting officer:- Sh. Ravinder Singh ( ADO/CC)  
Sh. Rajinder Atwal ( DO/CC)
8. Name & designation of officer  
From the building side:- Manager  
Old Heritage
9. Year of construction:- Old Heritage
10. Applicant's letter No:- ID No. 2024011900633 dated 19.01.24.  
Old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	N/A	15 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.0 mtr.	1.0 & 1.10 mtr. ✓	MR (old case)
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01 ✓	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 exit	1.25 & 1.20 mtr.	MR (old case)
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	06 Nos.	06 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR

✓ R

M/38

	3) ISI marking	ISI	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	NR	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floor	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM /	MR
	b) Head of pump	25 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltrs.	5,000 Ltr. /	MR

15.	<b>Exit Signage.</b>	Required	Provided ✓	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided ✓	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection systems provided in the said building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2021/15 dated 18/10/2021, under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval. 18/01/2024

Signature of the Inspecting Officer

*[Handwritten Signature]*  
25/1/24

Name :- Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

*[Handwritten Signature]*  
30/1/24

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Handwritten Signature]*  
Dy. C.F.O.

*[Handwritten Signature]*  
29/01/24

*[Handwritten Signature]*  
21/2/2024

*[Handwritten Signature]*  
Director

*[Handwritten Signature]*