



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/SZ/2024/ 87

Dated: 06/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Rattan Chand Arya Public School, Arya Samaj Mandir, Y Block, Sarojini Nagar, New Delhi-110023, building comprised of ground plus two upper floors, owned/occupied by Rattan Chand Arya Public School was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/254 dated 30/07/2020. The premises was re-inspection by the officer concerned by this department on 18/01/2024 in presence of Ms. Abha Khanduri (HOS) of the school and found that the said school premises have deemed compiled with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Group 'B' Education" with effect from 06/02/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/02/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
06/02

Copy to: -

1. The Principal, Rattan Chand Arya Public School, Arya Samaj Mandir, Y Block, Sarojini Nagar, New Delhi-110023
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc, may be got verified from concerned authorities.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its

10-19

## INSPECTION REPORT

1	Name & address of the building	Rattan Chand Arya Public School, Arya Samaj Mandir, Y Block, Sarojini Nagar, New Delhi-110023		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground + 2 upper floor only.		
4	Type of Case	Renewal		
5	Details of previous NOC	F.6/DFS/MS/School/2020/SZ/254 dated 30/07/2020		
6	Fire Safety directives Letter No.	DOE Circular 17/01/2005		
7	Date of inspection	18/01/2024		
8	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9	Name and designation of Officer from the building side	Mrs. Abha Khanduri (HOS)		
10	Year of Construction	2008		
11	Applicant letter No.	Email dated 05/01/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	Accessible	9m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	<b>a. Number of staircases</b>			
	• Upper floors	2 Nos	2 Nos	MR
	• Basements	N/A	N/A	N/A
	<b>b. Width of staircases</b>			
	• Upper floors	Required	1.25m & 1m	MR (old case)
	• Basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	One	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1m	1m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke managements System</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	06 Nos	10 Nos	MR
	• Types	ABC/W.CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	Required	02 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5m	5m	MR

2

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	Required	100mm	MR
	• Number of hydrants per floor	Required	02 Nos	MR
	• Hose Box	Required	02 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	NA
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 liters	5,000 liters	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection. The shortcomings earlier communicated by this department vide letter no. F.6/DFS/MS/School/2023/SZ/305 dated 12.06.2023 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the DOE circular, the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/254 date 30/07/2020, renewal under rules 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
29/01/24  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

*Mull*  
30/1/24

*CFO Singh*  
31/01/24

*Director*  
31/01/24

*AD(S)*

Sir, F.T letter is put up for your signature pl.  
*Santosh Kumar*  
05-02-24  
*Director*  
5/2/24