



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2024/WZ/ 90

Dated: 12/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Fashion Cosmetics located at M-138, Sector 3, DSIIDC Bawana, Delhi-110039 comprised of Basement, Ground plus Two upper floors owned/occupied by M/s Fashion Cosmetics was issued fire safety certificate vide Letter No. F6/DFS/MS/2020/Ind./59 dated 22/01/2021 have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 22/01/2024 in the presence of Sh. Ravish Arora and that the building premise is fit for occupancy under "Class Industrial Building Group G-2 (ii)" with effect from 12/02/2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 12/02/2024 at New Delhi by

  
(Atul Garg)  
Director  
Ph. 011-23414000  


**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Copy to :-

1. M/s Fashion Cosmetics at M-138, Sec-3, DSIIDC Bawana, Delhi-110039.

**INSPECTION REPORT**

1. Name & address of the building : M/s Fashion Cosmetics, M-138, Sector-3, DSIIIDC Bawana, Delhi- 110039.
2. Type of Occupancy : Industrial G-2(ii)
3. Building Comprised : B+Gr. + Two upper floors.
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No.DI/S/MS/2020/Ind./59 Dated- 22/01/2021
6. Fire Safety directives letter No : As per N-7 dated 19/11/2017
7. Date of inspection : 22/01/2024
8. Name of Inspecting Officer : R.K. Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Ravish Arora
10. Year of Construction : 2017
11. Applicant's letter No. : E Mail ID, Dated-15/01/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6 m	Provided	MR
	• Gate width	5 m	Directly Accessible	NA
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floor	1.25 m & 0.75 m	Provided	MR
	• Basements	1.25m & 0.75m	Provided	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	NA	NA	NA
		1.00 m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floor	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	07	Provided	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA



	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2020/Ind./59 dated 22/01/2021 under rule 37 of the Delhi Fire Service Rules, 2010.

*[Signature]*  
ADO/B.W.  
5/2/24

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

*[Signature]*  
8/2/2024

*[Signature]*  
8/2/2024

*[Signature]*  
8/2/2024

*[Signature]*  
8/2/24

*[Signature]* Any other, FT letter in pps for

Phase 1  
*[Signature]*  
12/2/24

*[Signature]*  
11/2/24

Sl. No. 507  
Date 8/2/2024