

C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/SZ/2024/90

Dated: 09/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School, Hastal, New Delhi-110059, having three blocks namely A, B & C Block, A & C block comprised of ground plus one upper floor & Block B comprised of ground plus three upper floors, owned/occupied by Govt. of NCT of Delhi was issued FSC by this department vide letter no. F.6/DFS/MS/School/2021/SZ/75 dated 01.02.2021. The school building was re-inspected by the officer concerned of this department on 06.02.2024 in the presence of Smt. Minakshi Shrivastava (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....09/02/2024..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
9/2/24

Copy to:-

1. The Principal, Govt. Girls Sr. Sec. School, Hastal, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Hastal Village, New Delhi- 59.
2. Building is comprised of : 2 blocks (A & C) G+1 & 1 block (B) G+3 Upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2021/SZ/75 dated 01.02.2021
6. Fire Safety Circular No. : N/A
7. Date of Inspection : 06.02.2024
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer from the building side : Smt. Minakhi Shrivastava (Principal)
10. Year of Construction : Before 2010, 2013-14 & 2017
11. Applicant's letter No : Form 'J' dated 06.02.2024

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per previous FSC	Provided at Site	Remarks
1	Access to building	06 m	09 m	MR
	• Road width	4.5 m	5.0 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	07 no.	07 no.	MR
	• Upper Floor	2 Nos	2 Nos	MR
	➤ A-Block G+1	2 Nos.	2 Nos.	MR
	➤ B-Block G+3	3 Nos.	3 Nos.	MR
	➤ C-Block G+1	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.5 M	1.55 & 1.41 M	MR
	➤ A-Block G+1	1.5 M	1.75 M each	MR
	➤ B-Block G+3	1.5 M	2 no. of 1.54 & 1 no. of 1.51 m	MR
	➤ C-Block G+1	N/A	N/A	N/A
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	2 Nos.	2 Nos.	MR
	e. Width of Corridor	1.5 m	1.5,1.58,1.8 & 3.8 m	MR
	f. Door Size (double doors)	1.0 M	.95,1.0 M,1.13 & 1.15 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural	MR
5.	Fire Extinguishers			
	• Total numbers	32 Nos.	32 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

N/36

6	First-aid-Hose Reels. Block B	2 Nos.	2 Nos.	MR
	Total numbers of each floor	30 M	30 M	MR
	• Length of hose reel hose	5 MM	5 MM	MR
	• Nozzle diameter			
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level Block B			
	➤ Discharge of pump	450 LPM	450 LPMX2	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting. Block B			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2021/SZ/75 dated 01.02.2021, renewal under the rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav

16/2/2024

Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- ADO (JKP)

DO(SW) *[Signature]*
7/2/24

CFO (S2) *[Signature]*
7/2/2024

Director *[Signature]*
8/2/24

[Signature]