

C-97

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2022/492

Dated : 28/10/2022

FIRE SAFETY CERTIFICATE

Certified that the M/S Krishana Dx. Guest House located at 43, Arakashan Road, Pahar Ganj, New Delhi comprised of Ground + 05 Upper floors, Ground floor (Reception + 08 guest rooms + office), 1st floor to 3rd floor (13 guest rooms at each floor), total 47 guest rooms. The FSC was earlier granted by this department vide letter No.F6/DFS/MS/GH/2019/2200 dated 22/11/19 for 47 guest room upto third floor only. Now, the premises was re-inspected by the officer concerned of this department on 20/10/22 in the presence of Nitin Goel and found that the said guest house building having been given an affidavit dated 05.11.2019 regarding not to use any floor above third floor, has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 Ground floor (Reception + 08 guest rooms + office), 1st floor to 3rd floor (13 guest rooms at each floor), total 47 guest rooms up to third floor only, with effect from 28/10/2022 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued.....28/10/2022.....at New Delhi by.


(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi. to kindly ensure the occupancy and deviation if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID NO. 2022041907500 dated 19.04.2022 & mail id hotelkrishnadeluxe@gmail.com dated 01.09.2022.
3. The Manager, M/S Krishana Dx. Guest House, 43, Arakashan Road, Pahar Ganj, New Delhi

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

- | | |
|--|---|
| 1. Name & address of the building | M/S Krishana Dx. Guest House located at 43, Arakashan Road, Pahar Ganj, New Delhi |
| 2. Type of occupancy:- | Residential, Sub Division-A-1
Gr. + 05 Upper floors (total 47 Guest rooms)
Ground floor (Reception + 08 guest rooms + office),
1st floor to 3rd floor (13 guest rooms at each floor),
4 th & 5 th floor given an affidavit dated 05.11.2019 regarding not to use any floor above third floor. |
| 3. Type of case:- | Renewal |
| 4. Details of previous FSC:- | No. F6/DFS/MS/GH/2019/2200 dated 22/11/19 |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 20/10/22 |
| 7. Name of the inspecting officer:- | Sh. Ravinder Singh (ADO/CC) |
| 8. Name & designation of officer
From the building side:- | Sh Nitin Goel
1981 |
| 9. Year of construction:- | |
| 10. Applicant's letter No:- | id no. 2022041907500 dated 19.04.2022 & mail id hotelkrishnadeluxe@gmail.com dated 01.09.2022. |

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr. Approx.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.50 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	125 cms & 150 cms	N/A
	F. Door size	N/A	85x220 cms	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural/exhaust	MR

5.	Fire Extinguishers			
	1) Total numbers	17 Nos.	17 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO	Required	Provided	MR
	2) Location of main panel	Ground	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Ground	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

N/38

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	50,000 ltr.	50,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. no. F6/DFS/MS/GH/2019/2200 dated 22/11/19, upto third floor only under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name: - Ravinder Singh
Designation: - ADO (CC)

Dogra
29/1/22
Dy. Commr (P/2)

F.T. please.

ADO (CC)

Ring
26/10