

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/SZ/2024/ 92

Dated: 09/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Virndavan Public School located at WZ-415, Hastal Village, New Delhi-110059, comprised of ground plus two upper floors, having total 12 rooms (including Class rooms & offices etc.), was issued FSC by this department vide letter No. F6/DFS/MS/School/2019/SZ/454 dated 28.02.2019. The School building was re-inspected by the officer concerned of this department on 06.02.2024 in the presence of Sh. Satish Tyagi (Manager) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....09/02/2024.... at New Delhi.


 (Anil Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Manager, Vrindavan Public School at WZ-415, Hastal Village, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Vrindavan Public School, WZ-415, Hastal Village, New Delhi-110059
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus two upper floors
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/2019/SZ/454 dated 28.02.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 06.02.2024
8. Name of Inspecting Officer : R.K. Yadav, ADO (JKP)
9. Name and designation of officers
From the building side : Sh. Satish Tyagi (Manager)
10. Year of Construction : Before 2006
11. Applicant's letter No. : Letter No. 101/24 dated 30.01.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 28.02.2019	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5 mtrs N/A	4.5 mtrs Directly accessible from road N/A	M/R, old case MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No. N/A	02 No's N/A	M/R No basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 & 0.75 mtr N/A	1.38 & 1.2 mtrs N/A	M/R, old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01	01	M/R
	e. Width of Corridor	1.50 mtrs	1.22 mtrs.	M/R, old case
	f. Door Size	1.0 mtrs	1.0 mtrs	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation Provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 no's ABC/CO2 type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

N/15

7.	Automatic fire detection and alarming system			N/A	N/A
	• Type of detectors	N/A	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A	N/A
8.	MOEFA			N/A	N/A
9.	Public Address System			N/A	N/A
10.	Automatic Sprinkler System				
	• Basement	N/A	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A	N/A
11.	Internal Hydrants				
	• Size of riser/down-comer	N/A	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A	N/A
12.	Yard Hydrants				
	• Total number of hydrants	N/A	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A	N/A
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A	N/A
	• Terrace level				
	➤ Discharge of pump	450 LPM	Provided	M/R	M/R
	➤ Head of the pump	40 mtrs	Provided	M/R	M/R
	➤ Power Supply	N/A	Provided	M/R	M/R
	➤ Auto Starting of pump	N/A	Provided	M/R	M/R
14.	Captive Water Storage for fire fighting				
	• Underground tank capacity	N/A	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltrs	Provided	M/R	M/R
		Required	Provided	M/R	M/R
15.	Exit Signage.			(No Lift)	
16.	Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A	N/A
17.	Standby power supply				

18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/454 dated 28.02.2019, renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 Signature of Inspecting Officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

Divisional Officer (South West)
[Signature]
 8/21/24

CPD (S2)
[Signature]
 8/21/24

Director
[Signature]
 9/2/24

[Signature]