



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/WZ/2024/INDL/91

Dated:- 13/02/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Asian Paints Ltd., Located at Khasra No. 111/6, & 111/15, Phirni Road, Mundka, New Delhi-110041, comprised of Ground Floor only owned/occupied by M/s. Asian Paints Ltd., was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/WZ/2021/88 dated 03/02/2021. The said premises was re inspected by the officer concerned of this department on 23/01/2024 in the presence of Sh. Jagjit, Supervisor and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class "Storage" Group-H with effect from 13/02/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 13/02/2024 at New Delhi by.

(Atul Garg)
Director

Tel No. 011-23414000

Copy to: -

1. The Authorized Signatory, M/s. Asian Paints Ltd., Khasra No. 111/6 & 111/15, Phirni Road, Mundka, New Delhi-110041.

Following Fire Safety Directive must be adhered to :-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities. In case of deviation the NOC be treated as Null & Void.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : **M/s. Asian Paints** Located at **Kh. No. 111/6, 111/15, Phirni Road, Mundka, New Delhi-110041**
2. Type of Occupancy : Storage (Group-II)
3. Type of Case : Renewal (Ground Floor only)
4. Details of previous NOC : F6/DFS/MS/WZ/2021/88 dated 03/02/2021
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 23/01/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Jagjit, Supervisor
9. Year of Construction : 2011
10. Applicant's letter no. : email dated 11/01/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	BBJ./NBC (Part-IV) Requirements/ as per FSC dated 03/02/2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	12 m	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	03 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.50 m	3.0 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided (Hall)	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	25 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/Beam	Beam	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Ground Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Ground Floor	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	05	Provided	MR
	• Hose Box	05	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	05	10	MR
	• Hose Box	05	10	MR
13.	Pumping Arrangements:			
	• Ground Level	2280 lpm	Provided	MR
	• Discharge of main pump	65 m	Provided	MR
	➤ Head of main pump	01	Provided	MR
	➤ Number of main pumps	220 lpm	Provided	MR
	➤ Jockey pump out put	65 m	Provided	MR
	➤ Jockey pump head	2280 lpm	Provided	MR
	➤ Standby Pump out put	65 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	50,000 ltrs.	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


N-22

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.



In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/W7/2021/88 dated 03/02/2021 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.


 Aman Kumar Lathar
 ADO (JWP)

~~DCFO (W2)~~
 16 West...
 4.01.24...


 29/01/2024
 Director / W2
 30/1/24
 ADO/JWP

For, R.T. letter is put-up for your signature M.
 Director / W2


 02/02/24
 ADO (JWP)