

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/48

Dated...12/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of **M/s Canvas V** located at **T-540, GF, Panchshila Park, Malviya Nagar, New Delhi 110017** comprised of Ground floor owned/occupied by A Unit of Divij Culinary Pvt Ltd, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 02/02/2024 on in the presence of Mr. Manoj Kumar and that the premise is fit for occupancy class **Group-D Assembly Building** (Restaurant at Ground Floor only) and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/02/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Public Health Department, MCD, Green Park Zone, New Delhi-110016 (Ref. MHA Portal 2023112118736 dated 15/01/2024)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	M/s Canvas V (A Unit of Divij Culinary Pvt Ltd) located at T-540, Panchshila Park, Malviya Nagar, New Delhi 110017		
2	Type of Occupancy	Eating house running at Ground Floor only		
3	Building Comprised of	Ground floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	02/02/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Manoj Kumar		
10	Year of construction	1956	Restt. Running at Ground floor only	
11	Applicant letter No.	MHA Portal 2023112118736 dated 15/01/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL- 2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"><li>Road width</li><li>Gate width</li><li>Width of internal road</li></ul>	09m N/A N/A	Provided N/A N/A	MR N/A N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Restaurant at Ground floor only		
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 mtr each	1.50m & 1.50m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"><li>Fire check door.</li><li>Sealing of electrical shafts.</li><li>Fire rating of shaft door.</li><li>Water curtain</li><li>Fire dampers.</li></ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"><li>Basement</li><li>Upper floors</li></ul>	N/A N/A	N/A N/A	N/A N/A
5	Fire Extinguishers.			
	<ul style="list-style-type: none"><li>Total numbers</li><li>Types</li><li>ISI Marking</li></ul>	06 Nos ABC/CO <sub>2</sub> ISI marked	06 Nos ABC-04 Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"><li>Total numbers on each floor.</li><li>Length of hose-reel hose.</li></ul>	One 30m	Provided Provided	MR MR

	• Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Ground/ upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	100mm	Provided	MR
	• Number of Hydrant per floor	01 Nos	Provided	MR
	• Hose box.	01 Nos	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ 'Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	20,000 Ltrs	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A

18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

Signature of the inspecting Officer  
Name: Sh. M.K Sharma  
Designation: DO (South)

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

CFO (HQ)

*[Handwritten signatures and dates]*  
8/2/24  
Director  
8/2/24

*[Handwritten signature]*  
ADDO

As approved, F.F. letter is put up for  
your signature OI

*[Handwritten signatures and dates]*  
Director  
12/2/24  
1/14  
9/2

*[Handwritten signature]*  
13/2/24