



**FIRE SAFETY CERTIFICATE**

Certified that the M/s Frankfinn Aviation Private Limited, located at, E- 354, Nirman Vihar, Delhi-110092 running at upper ground & first floor comprised building of Basement (Store), Stilt (Parking) plus upper ground plus three upper floors only, owned/occupied M/s Frankfinn Aviation Private Limited have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 29/01/2024 in the presence of Mr. Vicky (Manager) and that the building /premises is fit for occupancy class "Educational" (Group-B) with effect from 16/02/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued 16/02/2024 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
o/c @

**Copy to: -**

1. The Manager, Frankfinn Aviation Private Limited, located at, E- 354, Nirman Vihar, Delhi - 110092.

**Condition for the validity of fire safety certificate**

1. Fire Safety Certificate is valid for upper ground & first floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. Basement shall be used strictly as per Building By-Laws 1983.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

## INSPECTION REPORT

1	Name & address of the building	M/s Frankfinn Aviation Private Limited, located at, E- 354, Nirman Vihar, Delhi-110092.		
2	Building is comprised of	Basement (Store) + Stilt (Parking) + Upper Ground + 03 upper floors only. ( Coaching Classes is running at Upper Ground & first floor only)		
3	Type of occupancy	Educational Building (Coaching Classes)		
4	Type of case	New Case		
5	Details of previous FSC	Nil		
6	Fire safety directives letter no.	NBC Part IV		
7	Date of inspection	07.02.2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Vicky (Manager)		
10	Year of construction	2005		
11	Applicant's letter no.	Outdoor dairy No. 11600 dated 05.01.2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	6.0 mtrs.	On Road	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	<b>A Number of staircases</b>			
	a Upper floor	02 nos.	02 nos.	MR
	b Basement	N/A	N/A	N/A
	<b>B Width of staircases</b>			
	a Upper floor	1.50 mtrs.	1.50 mtrs. each	MR
	b Basement	N/A	N/A	N/A
	<b>C Protection of exits</b>			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	02 nos.	MR
	E Width of corridor	Required	Provided	MR
	F Door size	Required	Provided	MR
3	<b>Compartmentation:</b>			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
	A Basement	Required	Provided (Exhaust Fan)	MR
	B Upper floor	Required	Natural Ventilation	MR

(W)

<b>5.</b>	<b>Fire Extinguisher:</b>			
	<b>A</b>	Total numbers	06 nos.	08 nos. ✓ MR
	<b>B</b>	Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub> MR
	<b>C</b>	ISI marking	ISI Marked	ISI Marked MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
	<b>A</b>	Total numbers each floor	01 no.	01 no. ✓ MR
	<b>B</b>	Length of hose reel hose	30 mtrs	30 mtrs MR
	<b>C</b>	Nozzle diameter	5 mm	5 mm ✓ MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
	<b>A</b>	Type of detectors	Smoke	Provided N/A
	<b>B</b>	Location of main panel	Ground floor	Provided N/A
	<b>C</b>	Location of repeater panel	N/A	N/A N/A
	<b>D</b>	Alternate source of power	N/A	Provided N/A
	<b>E</b>	Hooters	N/A	Provided N/A
<b>8</b>	<b>MOEFA:</b>		N/A	Provided N/A
<b>9</b>	<b>Public Address System:</b>		N/A	N/A N/A
<b>10</b>	<b>Automatic Sprinkler System:</b>			
	<b>A</b>	Basement	Required	Provided MR
	<b>B</b>	Upper floor	Required	Provided MR
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A N/A
<b>11</b>	<b>Internal Hydrants:</b>			
	<b>A</b>	Size of riser/down-comer	100 mm	100 mm MR
	<b>B</b>	Number of hydrants per floor	01 no.	01 no. ✓ MR
	<b>C</b>	Hose box	01 no.	01 no. ✓ MR
<b>12</b>	<b>Yard Hydrants:</b>			
	<b>A</b>	Total number of hydrants	N/A	N/A N/A
	<b>B</b>	Hose box	N/A	N/A N/A
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
	<b>A</b>	Discharge of main pump	N/A	N/A N/A
	<b>B</b>	Head of main pump	N/A	N/A N/A
	<b>C</b>	Number of main pumps	N/A	N/A N/A
	<b>D</b>	Jockey pump out put	N/A	N/A N/A
	<b>E</b>	Jockey pump head	N/A	N/A N/A
	<b>F</b>	Standby pump out put	N/A	N/A N/A
	<b>G</b>	Standby pump head	N/A	N/A N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A N/A
	<b>I</b>	Pump house access	N/A	N/A N/A
<b>2</b>	<b>Terrace Level</b>			
	<b>A</b>	Discharge of pump	450 LPM	450 LPM ✓ MR
	<b>B</b>	Head of the pump	40 M	40 M ✓ MR
	<b>C</b>	Power supply	Required	Provided MR
	<b>D</b>	Auto starting of pump	Required	Provided MR

<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
		Required	Provided	MR
<b>15 Exit Signage:</b>				
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
		N/A	N/A	N/A
<b>17 Standby Power Supply:</b>				
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
		N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>				
		N/A	N/A	N/A

As per direction of FP wing inspection of the building was carried out.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO (L.N)

DY.CPO/NDZ

e.F.P.

KMP  
09/02/24

KMP  
12/2/2024

Amelw

KMP  
14/2/24

Amelw