



No.F6/DFS/MS/School/SZ/2024/ 96

Dated: 13/02/2024

### FIRE SAFETY CERTIFICATE

Certified that the **G.D. Goenka Public School** located at **J -Block, Sarita Vihar, New Delhi-76**, comprised of **Basement + Stilt + Ground + 3 upper floors** was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/SZ/144 dated 19.02.2021. The school building was re-inspected by a team of officers concerned of this department on 07.02.2024 in the presence of Mr. T.R. Garg (Owner) and found that school building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the school premises/building comprised of **Basement + Stilt + Ground + 3 upper floors** is fit for occupancy of Group B "**Educational Building**" with effect from 13.02.2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 13.02.2024 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service

#### Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, G.D. Goenka Public School located at J -Block, Sarita Vihar, New Delhi-76.

#### Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per NBC/UBBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

# INSPECTION REPORT

1	Name & address of the building	G.D. Goenka Public School located at J -Block, Sarita Vihar, New Delhi-76.		
2	Building is comprised of	Basement + Stilt + Ground + 3 upper floors		
3	Type of occupancy	Group B -Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/SZ/144 dated 19.02.2021		
6	Fire safety direction letter no.	F6/DFS/MS/BP/2013/102 dated 30.05.2013		
7	Date of inspection	07.02.2024		
8	Name of the inspecting officers	Manoj Kumar Sharma, DO (SD) & Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. T.R. Garg (Owner)		
10	Year of construction	2014		
11	Applicant's letter no.	Outdoor diary no. 12386 dated 30.01.2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	6.0 mtrs	6.0 mtrs.	MR
	B Gate width	5.0 mtrs	6.15 mtrs, 6.15 mtrs & 8.0 mtrs	MR
	C Width of internal road	6.0 mtrs	Provided	MR
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	02 nos.	02 nos.	MR
	b Basement	02 nos.	02 nos.	MR
	B Width of staircases			
	a Upper floor	2.0 mtrs each	Provided	MR
	b Basement	2.0 mtrs each	Provided	MR
	C Protection of exits			
	a Fire check door	Required	Provided	MR
	b Pressurization	Required	Provided	MR
	D No. of continuous staircases to terrace	2 nos.	Provided	MR
	E Width of corridor	1.5 mtrs	Provided	MR
	F Door size	1.0 mtrs for class room	1.0 mtrs for class room	MR
3	<b>Compartmentation:</b>			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	Required	Provided	MR
	C Fire rating of shaft door	Required	Provided	MR
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
	A Basement	30 ACPH	Provided	MR
	B Upper floor	12 ACPH	Provided	MR
5.	<b>Fire Extinguisher:</b>			
	A Total numbers	20 nos.	24 nos.	MR
	B Types	CO <sub>2</sub> , W.CO <sub>2</sub> & ABC	CO <sub>2</sub> , W.CO <sub>2</sub> & ABC	MR
	C ISI marking	Required	Provided	MR
6	<b>First-Aid-Hose Reel:</b>			
	A Total numbers of each floor	2 nos.	2 nos.	MR
	B Length of hose reel hose	30 mtrs	30 mtrs	MR
	C Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	Smoke	NA
	B	Location of main panel	NA	At Ground	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	Audible in entire building	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		Required	Provided	NA
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floors	Required	Provided	MR
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	Provided	MR
	B	Number of hydrants per floor	2 nos.	Provided	MR
	C	Hose box	2 nos.	Provided	MR
12	Yard Hydrants:				
	A	Total number of hydrants	Required	2 nos.	MR
	B	Hose box	Required	2 nos.	MR
13	Pumping Arrangements:				
A	Ground level				
	a	Discharge of main pump	NA	NA	NA
	b	Head of main pump	NA	NA	NA
	c	Number of main pumps	NA	NA	NA
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump head	NA	NA	NA
	h	Auto starting /manual stopping	NA	NA	NA
	i	Pump house access	NA	NA	NA
B	Terrace Level				
	a	Discharge of pump	1620 LPM	Provided	MR
	b	Head of the pump	40 mtrs	Provided	MR
	c	Power supply	Required	Provided	MR
	d	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	25,000 ltrs	Provided	MR
15	Exit Signage:		Required	Provided	MR
16	Provision for Lifts:				
	A	Pressurization of lift shaft	Required	Provided	MR
	B	Pressurization of lift lobby	Required	Provided	MR
	C	Communication in lift car	Required	Provided	MR
	D	Firemen's grounding switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR

17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
	A Total area	NA	NA	NA
	B Location	NA	NA	NA
19	Fire Control Room:			
	A Detector system panel	NA	NA	NA
	B Flow switch panel	NA	NA	NA
	C PA system panel	NA	NA	NA
	D Battery backup	NA	NA	NA
	E Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/144 dated 19.02.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

*Manoj*

Signature of the Inspecting Officer  
Name Manoj Kumar Sharma  
Designation DO (SD)

*Rajesh*  
08/2/24

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

CFD  
+

*Manoj*  
12/2/2024

*Director*

*12/2/24*

*ADP*

*M. L. S.*