

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/SZ/2024/ 109

Dated: 15/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Senior Secondary School (Id- 1617030), Village Baprola, New Delhi-110043, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2019/SZ/2015 dated 21/10/2019 (Combined for Girls & Boys school), now having 03 blocks namely Red building block is comprised of ground plus three upper floors and Saraswati block and Kalpana Chawla block are comprised of ground plus one upper floor each, owned/occupied by Govt. NCT of Delhi, was inspected by the officer concerned of this department on 06.02.2024 in the presence of Ms. Anita Bahl (Vice Principal) and found that the School building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....15/02/2024..... at New Delhi.


 (ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE
 Reg-

Copy to:-

1. The HOS, Govt. Girls Senior Secondary School (Id- 1617030) at Baprola, New Delhi- 43.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Secondary School (Id- 1617030), Baprola, New Delhi-110043.
2. Building comprised of : Red building block- ground plus three upper floors & Saraswati block & Kalpana Chawla blocks are comprised of ground plus one upper floor each.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/2015 dated 21/10/2019 (Combined)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 06.02.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Ms. Anita Bahl (HOS/Vice Principal)
10. Year of Construction : 2016-2017
11. Applicant's letter No. : GBSSS/SCH/BAP/2023/423 dated 02.11.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 m) 4.5 mtrs. N/A	Provided Provided N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Red Bldg. Block = 4 No. Saraswati Block = 2 Nos. K. Chawla Block = 1 No. N/A	Provided N/A	MR, old accepted N/A
	<ul style="list-style-type: none"> Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	Red Bldg Block = 1.5M each Saraswati Block = 1.5 m each K. Chawla Block = 1.5m	Red Bldg Block = 1.5M each, Saraswati Block = 1.2 & 1.4 m K. Chawla Block = 1.2 m	MR, old accepted
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 each block	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1.2 m & 1.0 m	1.2 m & 1.10 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	36 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

6.	First-Aid Hose Reels	Red Building Block		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Stilt floor Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants	Red Building Block		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm Three Three	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		Red Building Block		
		900 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for firefighting	Red Building Block		
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity each block 	N/A N/A N/A N/A 10000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note:- Earlier Govt. Boys Sr. Sec. School & Govt. Girls Sr. Sec. School were running in this premises, Now the premises has been divided in two parts by brick wall and two separate schools are running there.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2019/SZ/2015 dated 21/10/2019, renewal in accordance with the Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

R.K. Yadav
08/2/2024
Signature of the Inspecting Officer
Name - R.K. YADAV
Designation- ADO (JKP)

Divisional Officer (South West)

Ch 9/2/24
(Fol/s2)
12/2/2024
Director
10/2/24

Ado/2/24