

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2024/ 112

Dated: 15/02/2024

FIRE SAFETY CERTIFICATE

Certified that the **Jeevan Public School, Pratap Vihar, Part-II, Kirari, Ext., Delhi-110086**, comprised of **02 Blocks, Ground + 02 & Ground + 03 upper floors**) owned/ occupied by **Jeevan Public School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **24.01.2024** in the presence of **Mr. Sumit Chaudhary** and that the building/ premise is fit for occupancy Group B Educational with effect from 15/02/2024 for a period of **three years**, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/02/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, Jeevan Public School, Pratap Vihar, Part-II, Kirari, Ext., Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.
3. The Executive Engineer Building, Narela Zone, North Delhi Municipal Corporation, Opp. Police Station, Narela, Delhi, 110040.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Jeevan Public School, Pratap Vihar, Part-II, Kirari, Ext., Delhi-110086.			
2. Type of Occupancy	Educational			
3. Type of Case	Additional/alternation (02 Blocks, Ground + 02 & Ground + 03 upper floors)			
4. Details of Previous NOC	(F.6/DFS/MS/2020/WZ/485 dated 09.11.2020. Previously NOC (02 Blocks, Ground + 02 upper floors))			
5. Fire Safety directives letter No	NBC Part-IV			
6. Date of inspection	24.01.2024.			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Sumit Chaudhary			
9. Year of Construction	1998, 2013 & 2023			
10. Applicant's letter No.	Online e-mail dated 05.10.2023.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m & 3.7m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Old Block-02 New Block-02	Old Block-02 New Block-02	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5mtr	Old Block-1.10 & 1.45m New Block-2 x1.70 mtr	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required New Block-02	Provided New Block-02	MR MR
	e. Width of Corridor	1.5m	1.55mtr	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	20nos.	20nos.	MR
	b) Types	ABC/CO2	ABC-20nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			

	a) Total numbers on each floor	01 each block	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm 01 each blk	100mm 01 each blk	MR
	b) Number of hydrants per floor	01 each block	01 each block	MR
	c) Hose Box	01 each block	01 each block	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm & 220lpm Old blk 450 lpm New blk	450lpm & 220lpm Old blk 450 lpm New blk	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	5000ltr old blk 10,000ltr new blk	5000ltr old blk 10,000ltr new blk	MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

MR
MR

a)	Pressurization of Lift Shaft	-NA-	-NA-	-NA-
b)	Pressurization of Lift lobby	-NA-	-NA-	-NA-
c)	Communication In lift Car	-NA-	-NA-	-NA-
d)	Fireman's Grounding Switch	-NA-	-NA-	-NA-
e)	Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
a)	Total Area	-NA-	-NA-	-NA-
b)	Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
a)	Detector System Panel	-NA-	-NA-	-NA-
b)	Flow Switch Panel	-NA-	-NA-	-NA-
c)	PA System Panel	-NA-	-NA-	-NA-
d)	Battery backup	-NA-	-NA-	-NA-
e)	Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]
30/1/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CPO/WZ

previously school complex was comprised of two blocks & each block was comprised of ground plus two upper floors each.
Now the school management have added one more floor to the third floor in one block & fire fighting system have been extended as reported by the inspecting officer.

Submitted for approval please

[Handwritten Signature]
6/1/24

JFOI... 435
Dated... 7/1/24

[Handwritten Signature]
8/1/24
Director

Thereon mark one copy to Ex Engr/m
also

DEPO/WL *[Handwritten Signature]*
9/1/24
ADO (Rohini)