

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6 DFS/MS/School/2024/SZ/104

Dated: 15 / 02 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that the **MCD (Coed) Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062 (School ID-1959127)** comprised of ground plus one upper floor was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ/547 dated 10/12/2020. The said premises was re-inspected by officer concerned of this department on 08/02/2024 in presence of Mr. Rajesh Verma (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No.F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class **"Educational Building"** Group-B, with effect from 15/02/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15 / 02 / 2024 at New Delhi by

(ATUL GARG)  
DIRECTOR

Delhi Fire Service

Copy to: -


1. The Principal, MCD (Coed) Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062
2. The Director of Education, MCD, Civic Centre Minto Road, New Delhi 110002

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Building Sanctioned authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	MCD (Co-ed) Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062 (ID-1959127)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground Plus One Upper Floor Only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2020/SZ/547 dated 10/12/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	08/02/2024		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rajesh Verma (Principal)		
10	Year of construction	2006		
11	Applicant letter No.	E-mail Dated 16/01/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular dated 01/03/2011 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6m	MR
	• Gate width	-N/A-	4m	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	Two	Two	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors.	1.50 m / 0.75 m	1.72m & 1.75m	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4	Smoke Management system.			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	Natural Ventilation	-N/A-
5	Fire Extinguishers.			
	• Total numbers	08 No 's	08 No 's	MR
	• Types	ABC / Co2	ABC	MR
	• ISI Marking	ISI Marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-

7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	<b>MOEFA / Siren</b>	-N/A-	Provided	-N/A-
9.	<b>Public Address System</b>	-N/A-	Provided	-N/A-
10.	<b>Automatic Sprinkler System</b>			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	<b>Captive water storage for firefighting.</b>			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	<b>Standby Power Supply</b>	-N/A-	-N/A-	-N/A-
18.	<b>Refuge Area</b>			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-

19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			
<p>The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the DOE Circular dated 01/03/2011, the FSC issued vide letter No F.6/DFS/MS/School/2020/SZ/547 dated 10/12/2020 renewal is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
<p style="text-align: right;">             Signature of the Inspecting Officer            Name : Sh. Rajesh Kumar            Designation: ADO (BCP)         </p>				

DO/SD

merit  
10/12/24

afp  
12/21/2024

Director

ADY/OLD

As approved, F-1. Letter is put up for  
your signature OI

1/14  
14/12/24

Director  
14/12/24  
mu