

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/School/SZ/2024/ 98

Dated: 14/02/2024

FIRE SAFETY CERTIFICATE

Certified that **Shokeen International School** located at **Chhawla, New Delhi- 110071**, having two blocks namely Old wing & Primary wing comprised of ground plus one upper floor & Admin block comprised of ground floor with small basement was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2021/SZ/School/228 dated 16.03.2021. The school building was re-inspected by the officer concerned of this department on 31.01.2024 in the presence of Sh. Kusum Rathor (Principal) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from 14/02/2024 for a period of three years subject to compliance of the conditions printed below.

Issued on 14/02/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service


Copy to: -

1. The Principal, Shokeen International School located at Chhawla, New Delhi- 110071.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : Shokeen International School at Chhawla, New Delhi- 71.
2. Type of Occupancy : Educational
3. Building Comprised of : Two blocks namely Old wing & Primary wing Ground plus one upper floor & Admin block ground floor with small basement
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2021/SZ/School/228 dated 16.03.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 31.01.2024
8. Name of the Inspecting Officers : R.K. Yadav, Asstt. Div. Officer (JKP)
9. Name and designation of officers from the building side : Sh. Kusum Rathor, Principal
9. Year of Construction : 2004
10. Applicant's letter No. : Form 'J' dated Nil


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per N/10	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	05 mts	MR, being old case
	• Gate width	4.5 mts	4.8 mts	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 nos each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 & 0.75 mts at each wing	Provided in both blocks	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 each block	Provided	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation Provided	MR
5	Fire Extinguishers			
	• Total numbers	11 nos.	17 nos.	MR
	• Types	ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	N/A	01 each floor	N/A
	• Length of hose reel hose	N/A	30 m	N/A
	• Nozzle diameter	N/A	5 mm	N/A
7	Automatic fire detection and alarming system Not required			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	N/A	220 lpm each block	N/A
	➤ Head of the pump	N/A	40 mts	N/A
	➤ Power Supply	N/A	Provided	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	2500 lts each block	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2021/SZ/School/228 dated 16.03.2021, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.



 01/2/2024
 Signature of the inspecting officer
 Name- R.K. Yadav
 Asstt. Div. Officer (JKP)

D.O. (SW)

What about basement staircase?

ADO (for ROR)

There is only one staircase of 40 sq. ft. for basement, having area less than 50 sq. meter. This basement is a part of administrative block. It is for storage only.


 09/2/2024

Deputy AD, 12/2/24

CO (SZ)

13/2/2024

Director

13/2/24

DO/SW