

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F.6/DFS/MS/SZ/Indl./2024/107

Dated: 19/02/2024

FIRE SAFETY CERTIFICATE

Certified that the **M/s Alankrit Handicrafts Pvt Ltd.** located at **Plot No 208, Okhla Industrial Area, Phase-III, New Delhi 110020** comprised of 02 Tier Basement, ground + Two upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Ind./SZ/2018/351 Dated 06/03/2018. The building was re-inspected by the officer concerned of this department on 07/02/2024 in the presence of Mr. Prateek and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class - G (Industrial occupancy)** with effect from 19/02/2024 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 19/02/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. M/s Alankrit Handicrafts Pvt Ltd. at Plot No 208, Okhla Industrial Area, Phase-III, New Delhi 110020
2. The Executive Engineer (Bldg.), Jal Vihar, Lajpat Nagar, New Delhi - 110024

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL- 2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL- 2016), if any.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/25

INSPECTION REPORT				
1	Name & Address of the Building	M/s Alankrit Handicrafts Pvt Ltd., Plot No 208, Okhla Industrial Area Phase- III, New Delhi 110020.		
2	Type of Occupancy	Industrial (Group - G)		
3	Building Comprised of	02 tier, Basements, Ground + 02 Upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Ind./SZ/2018/351 dated 06/03/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07/02/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Prateek		
10	Year of construction	2010		
11	Applicant letter No.	Outdoor diary no 12118 dated 22-01-2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	2 Nos	Provided	MR
	• Basement floor	2 Nos	Provided	MR
	b. Width of Staircase			
	• Upper floors	1.2 mtr	1.37 & 1.33 mtr	MR (old case)
	• Basement floor	1.2 mtr	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1 m	1 mtr (Final Exit)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	Required	22 Nos	MR
	• Types	ABC / Co2	ABC/ Co2 type	MR
	• ISI Marking	ISI Marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 at each floor	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Smoke/Heat	MR
		Required	Ground floor	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		Required	Provided	MR
		All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01 Nos.	Provided	MR
		01 Nos.	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	06 Nos	05 Provided	MR (old case)
		06 Nos	05 Provided	MR (old case)
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of main pump. 	55 M	Provided	MR
	<ul style="list-style-type: none"> Number of main pumps. 	01 No	Provided	MR
	<ul style="list-style-type: none"> Jockey Pump output. 	180 LPM	Provided	MR
	<ul style="list-style-type: none"> Jockey Pump head. 	55 m	Provided	MR
	<ul style="list-style-type: none"> Standby Pump output. 	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> Standby Pump head. 	55 M	Provided	MR
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> Head of pump. 	40 mtr	40 m	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	1,00,000 Ltrs	1,00,000 Ltrs	MR
	<ul style="list-style-type: none"> Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	20,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detection System Panel 	-NA-	-NA-	-NA-

<ul style="list-style-type: none"> Flow Switch Panel PA System Panel Battery backup. Building Floor plans 	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
20. Special Fire Protection Systems for Protection of Special Risks, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 88 dated 15/01/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Ind./SZ/2018/351 dated 06/03/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please

[Handwritten Signature]

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

[Handwritten Signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ) *[Handwritten Signature]*
21/2/2024

Director (DFS) *[Handwritten Signature]*

[Handwritten Signature]

As approved F-1 letter is pending for your signature P1

[Handwritten Signature]
19/2/2024

[Handwritten Signature]
19/2/2024
[Handwritten Initials]