

No. F6/DFS/MS/School/NDZ/2024/117

Dated: 19/02/2024

### FIRE SAFETY CERTIFICATE

Certified that the **Anglo Indian Public School located at Gharoli, Mayur Vihar - III, Delhi - 110096**, building comprised of ground plus three upper floors, owned / occupied by **Anglo Indian Public School**, was issued FSC vide letter No. F6/DFS/MS/School/2020/NDZ/338 dated 10/09/2020. The School building was re-inspected by the officer concerned of this department on 15/02/2024 in presence of Mr. Jagpal Singh Kasana (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational Building" (Group-B)** with effect from 19/02/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 19/02/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

O/C DELHI FIRE SERVICE

#### Copy to:-

1. The Principal, Anglo Indian Public School located at Gharoli, Mayur Vihar - III, Delhi -110096.
2. The Dy. Director of Education, D- Block, Anand Vihar, Delhi-110092.

### Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT					
01.	Name & address of the building		Anglo Indian Public School located at Gharoli, Mayur Vihar - III, Delhi - 110096.		
02.	Building is comprised of		Ground plus three uppers.		
03.	Type of occupancy		Group B - Educational Building		
04.	Type of case		Renewal		
05.	Details of previous FSC		F6/DFS/MS/School/2020/NDZ/338 dated 10/09/2020.		
06.	Fire safety directives letter no.		Circular no. 262-362 dated 17.01.2005.		
07.	Date of inspection		15/02/2024.		
08.	Name of the inspecting officers		Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side		Mr. Jagpal Singh Kasana (Manager)		
10.	Year of construction		1983		
11.	Applicant's letter no.		Outdoor Diary No. 12945 dated 09/02/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33		Old Circular Requirement	Provided at site	Remarks MR/NMR
01.	<b>Access to Building:</b>				
	A	Road width	6.0 mtrs.	01 Length hose form main road	MR
	B	Gate width	NA	NA	NA
	C	Width of internal road	NA	NA	NA
02.	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	02 nos.	02 nos.	MR
	b	Basement	NA	NA	NA
	B	Width of staircases			
	a	Upper floor	1.50 mtrs. or less	1.10 mtrs & 0.60 mtrs.	MR
	b	Basement	NA	NA	NA
	C	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 no.	01 nos.	MR
	E	Width of corridor	1.0 mtrs.	1.0 mtrs.	MR
	F	Door size	1.0 mtrs.	1.0 mtrs.	MR
03.	<b>Compartmentation:</b>				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
04.	<b>Smoke Management System:</b>				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA


20

<b>05.</b>	<b>Fire Extinguisher:</b>			
	<b>A</b>	Total numbers	08 nos.	10 nos. ✓ MR
	<b>B</b>	Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub> MR
	<b>C</b>	ISI marking	ISI Marked	ISI Marked MR
<b>06.</b>	<b>First-Aid-Hose Reel:</b>			
	<b>A</b>	Total numbers of each floor	01 no.	01 no. ✓ MR
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs. ✓ MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm ✓ MR
<b>07.</b>	<b>Automatic Fire Detection and Alarming System:</b>			
	<b>A</b>	Type of detectors	NA	NA NA
	<b>B</b>	Location of main panel	NA	NA NA
	<b>C</b>	Location of repeater panel	NA	NA NA
	<b>D</b>	Alternate source of power	NA	NA NA
	<b>E</b>	Hooters	NA	NA NA
<b>08.</b>	<b>MOEFA:</b>		Required	Provided ✓ MR
<b>09</b>	<b>Public Address System:</b>		NA	NA NA
<b>10.</b>	<b>Automatic Sprinkler System:</b>			
	<b>A</b>	Basement	NA	NA NA
	<b>B</b>	Upper floor	NA	NA NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA NA
<b>11.</b>	<b>Internal Hydrants:</b>			
	<b>A</b>	Size of riser/down-comer	100 mm	100 mm ✓ MR
	<b>B</b>	Number of hydrants per floor	01 no.	01 no. ✓ MR
	<b>C</b>	Hose box	01 no.	01 no. ✓ MR
<b>12.</b>	<b>Yard Hydrants:</b>			
	<b>A</b>	Total number of hydrants	NA	NA NA
	<b>B</b>	Hose box	NA	NA NA
<b>13.</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
	<b>A</b>	Discharge of main pump	NA	NA NA
	<b>B</b>	Head of main pump	NA	NA NA
	<b>C</b>	Number of main pumps	NA	NA NA
	<b>D</b>	Jockey pump out put	NA	NA NA
	<b>E</b>	Jockey pump head	NA	NA NA
	<b>F</b>	Standby pump out put	180 LPM	180 LPM ✓ MR
	<b>G</b>	Standby pump head	40 mtrs.	40 mtrs. ✓ MR
	<b>H</b>	Auto starting /manual stopping	NA	NA NA
	<b>I</b>	Pump house access	NA	NA NA
<b>2</b>	<b>Terrace Level</b>			
	<b>A</b>	Discharge of pump	450 LPM	450 LPM ✓ MR
	<b>B</b>	Head of the pump	40 mtrs.	40 mtrs. ✓ MR
	<b>C</b>	Power supply	Required	Provided MR
	<b>D</b>	Auto starting of pump	Required	Provided MR

14.	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	5,000 liters.	5,000 liters.	MR
15.	<b>Exit Signage:</b>	Required	Provided	MR
16.	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17.	<b>Standby Power Supply:</b>	NA	NA	NA
18.	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19.	<b>Fire Control Room:</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20.	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 262-362 dated 17.01.2005, the FSC issued vide letter no. F6/DFS/MS/School/2020/NDZ/338 dated 10/09/2020 is recommended to be renewed.



Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

Dy. CFO (NDZ)

*Yashwant Singh Meena*  
15/02/24

*C.F.O.*  
16/2/2024

*Director*  
16/2/24

*AD/LN*

F.T letter is setup for sign. Please

*Director*  
19/2/24

*Yashwant Singh Meena*

*Yashwant Singh Meena*  
16/2/2024