



FIRE SAFETY CERTIFICATE

Certified that the **Dashmesh Palace Banquet Hall** running at **first floor only**, building comprised of ground plus two upper floors (Ground floor Reliance Fresh departmental store & Second floor vacant) located at **C-35, Main Wazirabad Road, Bhajanpura, Delhi – 110053**, owned/ occupied by **Dashmesh Palace Banquet Hall** was granted FSC vide letter no. F6/DFS/MS/BQ/2019/2138 dated 14.11.2019. The Premises was re-inspected by the officer concerned of this department on 14.02.2024 in the presence of Mr. Gurmeet Singh (Manager) and found that the Industrial building have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and found that the building is fit for occupancy class “**Assembly Building**” (Group D) “**Banquet Hall**” with effect from 20/02/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 and also conditions printed below.

Issued 20/02/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
(u)

Copy to:-

1. The Manager, Dashmesh Palace Banquet Hall located at C-35, Main Wazirabad Road, Bhajanpura, Delhi - 110053.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2021090320084 dated 30/12/2023.

Conditions for the validity of Fire Safety Certificate:

1. **Fire Safety Certificate is valid for first floor only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| 1 | Name & address of the building | Dashmesh Palace Banquet Hall located at C-35, Main Wazirabad Road, Bhajanpura, Delhi - 110053. | | |
|------|--|--|------------------|---------------------------|
| 2 | Building is comprised of | Ground + 02 upper floors only. (Banquet Hall is running at First floor only) | | |
| 3 | Type of occupancy | Assembly Building (Banquet Hall) | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F6/DFS/MS/BQ/2019/2138 dated 14.11.2019 | | |
| 6 | Fire safety direction letter no. | NBC Part- IV | | |
| 7 | Date of inspection | 14.02.2024 | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena (ADO/ Laxmi Nagar) | | |
| 9 | Name of the designation of officer From the building side | Mr. Gurmeet Singh (Manager) | | |
| 10 | Year of construction | 2011 & 2018 | | |
| 11 | Applicant's letter no | MHA Application No. 2024020601265 dated 06/02/2024. | | |
| S.No | Minimum Standards on fire Prevention and fire safety requirements U/R 33 | NBC Part-IV Requirement | Provided at Site | Remarks MR/NM R |
| 1 | Access to building | | | |
| | a | Road width | 6.0 mtrs. | 30 mtrs. MR |
| | b | Gate width | NA | NA |
| | c | Width of internal road | NA | NA |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | A | Number of staircases | | |
| | | a | Upper floor | 02 nos. MR |
| | | b | Basement | NA |
| | B | Width of staircases | | |
| | | a | Upper floor | 2.0 mtrs. & 1.20 mtrs. MR |
| | | b | Basement | NA |
| | C | Protection of exits | | |
| | | a | Fire check door | NA |
| | | b | Pressurization | NA |
| | D | No. of continuous staircases to terrace | NA | NA |
| | E | Width of corridor | NA | NA |
| | F | Door size | 2.0 mtrs. | 2.0 mtrs. MR |
| 3 | Compartmentation | | | |
| | a | Fire check door | NA | NA |
| | b | Sealing of electrical shafts | N/A | N/A |
| | c | Fire rating of shaft door | N/A | N/A |
| | d | Water curtain | N/A | N/A |
| | e | Fire dampers | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | a | Basement | NA | NA |
| | b | Upper floor | Required | Ventilated MR |

| | | | | | |
|-----------|--|--------------------------------|-----------------------|-----------------------|----|
| 5. | Fire Extinguisher | | | MR | |
| | a | Total numbers | 12 nos. | 12 nos. | MR |
| | b | Types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | c | ISI marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | MR | |
| | a | Total numbers | 01 no. | 01 no. / | MR |
| | b | Length of hose reel hose | 30 mtrs. | 30 mtrs. / | MR |
| | c | Nozzle diameter | 05 mm | 05 mm | MR |
| 7 | Automatic fire detection and alarming system. | | | NA | |
| | a | Type of detectors | NA | NA | NA |
| | b | Location of main panel | NA | NA | NA |
| | c | Location of repeater panel | NA | NA | NA |
| | d | Alternate source of power | NA | NA | NA |
| | e | Hooter | NA | NA | NA |
| 8 | MOEFA | | Required | Provided | MR |
| 9 | Public address System. | | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | NA | |
| | a | Basement | NA | NA | NA |
| | b | Upper floors | NA | NA | NA |
| | c | Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | MR | |
| | a | Size of riser | 100 mm | 100 mm / | MR |
| | b | Number of hydrants per floor | 01 no. | 01 no. / | MR |
| | c | Hose Box | 01 no. | 01 no. / | MR |
| 12 | Yard Hydrants. | | | NA | |
| | a | Total number of hydrants | NA | NA | NA |
| | b | Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | | |
| | A | Ground Level | | | |
| | a | Discharge of main Pump | NA | NA | NA |
| | b | Head of Main Pump | NA | NA | NA |
| | c | Number of main pumps | NA | NA | NA |
| | d | Jockey pump out put | NA | NA | NA |
| | e | Jockey pump head | NA | NA | NA |
| | f | Standby pump out put | NA | NA | NA |
| | g | Standby pump head | NA | NA | NA |
| | h | Auto starting /manual stopping | NA | NA | NA |
| | i | Pump House Access | NA | NA | NA |
| | B | Terrace Level | | | |
| | a | Discharge of pump | 900 LPM | 900 LPM / | MR |
| | b | Head of the Pump | 40 mtrs. | 40 mtrs. / | MR |
| | c | Power supply | Required | Provided | MR |
| | d | Auto Starting of pump | Required | Provided | MR |


W

So

| | | | | |
|----|---|----------------|----------------|----|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| a | Underground tank capacity | NA | NA | NA |
| b | Draw-off connection | NA | NA | NA |
| c | Fire service inlet | NA | NA | NA |
| d | Access to tank | NA | NA | NA |
| e | Overhead Tank capacity | 10,000 liters. | 10,000 liters. | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| a | Pressurization of Lift Shaft | NA | NA | NA |
| b | Pressurization of Lift lobby | NA | NA | NA |
| c | Communication in lift car | NA | NA | NA |
| d | Firemen's grounding switch | NA | NA | NA |
| e | Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| a | Total area | NA | NA | NA |
| b | Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| a | Detector system panel | NA | NA | NA |
| b | Flow switch panel | NA | NA | NA |
| c | PA system panel | NA | NA | NA |
| d | Battery backup | NA | NA | NA |
| e | Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC Part- IV the FSC issued vide letter no. F6/DFS/MS/BQ/2019/2138 dated 14.11.2019 is recommended to be renewed.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

By: CFO (NDZ)

C.F.O.

Rivp
15/02/24

Director
16/2/24

ADU LN

F.T Letter is attached for sign. Please

Director
19/01/24

16/2/2024

Uploaded
21/02/24