



FIRE SAFETY CERTIFICATE

Certified that the **Dr. Akhilesh Das Gupta Institute Professional Studies** located at, **FC.26, Shastri Park, New Delhi - 110053**, building comprised of five floors i.e. 1, 2, 3, 4 & 5 blocks (2nd block having basement, ground plus floor upper floor and 1st, 3rd, 4th & 5th blocks having basement, ground plus three upper floors) owned / occupied by **Babu Banarasi Das Educational Society**, was issued FSC vide letter No. F6/DFS/MS/NDZ/2021/01 dated 05/02/2021. The premises was re-inspected by the officer concerned of this department on 16/02/2024 in presence of Mr. Dilip Singh (Sr. Deputy Director) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group B "Educational Building" with effect from 23/02/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 23/02/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Mr. Dilip Singh (Sr. Deputy Director), Dr. Akhilesh Das Gupta Institute Professional Studies located at, FC.26, Shastri Park, New Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any
7. Basement shall be used as per NBC/UBBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

M/19

01.	Name & address of the building	Dr. Akhilesh Das Gupta Institute Professional Studies located at, FC.26, Shastri Park, New Delhi - 110053.		
02.	Building is comprised of	B+G+4 (Building is divided into 05 Blocks i.e. 1,2,3,4 & 05 Blocks 2 nd Block B+G+4 & 1,3,4 & 05 Blocks B+G+3)		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/NDZ/2021/01 dated 05/02/2021.		
06.	Fire safety directives letter no.	F6/DFS/MS/BP/2010/1207 dated 26/04/2010.		
07.	Date of inspection	16/02/2024		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mr. Dilip Singh (Sr. Deputy Director)		
10.	Year of construction	2010 & 2005		
11.	Applicant's letter no.	Outdoor Diary no. 12556 dated 01/02/2024.		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Directive Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	12 mtrs.	30 mtrs.	MR
	B Gate width	4.5 mtrs	6.0 mtrs	MR
	C Width of internal road	6.0 mtrs	6.0 mtrs	MR
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor block 1 st	03 nos.	04 nos.	MR
	Upper floor block 2 nd	03 nos.	03 nos.	MR
	Upper floor block 3,4 & 5	02 nos.	02 nos.	MR
	b Basement block 1 st	03 nos.	04 nos.	MR
	Basement block 2 nd	03 nos.	03 nos.	MR
	Basement block 3,4 & 5	02 nos.	02 nos. Ramp in 1 st & 2 nd block	MR
	B Width of staircases			
	a I. Upper floor	1.50 mtrs each	1.50 mtrs. each	MR
	b Basement	1.50 mtr	1.50 mtrs. each Ramp 4.40 mtrs	MR
	C Protection of exits			
	a Fire check door	Required	Provided	MR
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	1 no. each block	02 nos. each block	MR
	E Width of corridor	2.0 mtrs.	02 mtrs.	MR
	F Door size	1.0 mtrs	1.0 mtrs	MR
03.	Compartmentation:			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	Required	Provided	MR
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
04.	Smoke Management System:			
	A Basement	Required	Provided	MR
	B Upper floor	Required	Provided	MR

W

05. Fire Extinguisher:				
A	Total numbers	53 nos.	58 nos.	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
06. First-Aid-Hose Reel:				
A	Total numbers of each floor	Block 1 & 2= 02 nos. Block 3,4 & 5= 01 no.	Block 1 & 2= 02 nos. Block 3,4 & 5= 01 no.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
08.	MOEFA:	Required	Provided	MR
09	Public Address System:	Required	Provided	MR
10. Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11. Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	Block 1 & 2= 02 nos. Block 3,4 & 5= 01 no.	Block 1 & 2= 02 nos. Block 3,4 & 5= 01 no.	MR
C	Hose box	01 nos.	Provided	MR
12. Yard Hydrants:				
A	Total number of hydrants	10 nos.	Provided	MR
B	Hose box	10 nos.	Provided	MR
13. Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	2850 LPM	2850 LPM	MR
B	Head of main pump	80 m	80 m	MR
C	Number of main pumps	01 no	01 no	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	80 m	80 m	MR
F	Standby pump out put	2850 LPM	2850 LPM	MR
G	Standby pump head	80 m	80 m	MR
H	Auto starting /manual stopping	Required	Provided	MR
I	Pump house access	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	450 LPM each block	450 LPM each block	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR


W


W,



14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	1,00,000 liters	1,00,000 liters	MR
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	25,000 liters.	25,000 liters.	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	Required	Provided	MR
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	Required	Provided	MR
D	Firemen's grounding switch	Required	Provided	MR
E	Lift signage	Required	Provided	MR
17. Standby Power Supply:		Required	Provided	MR
18. Refuge Area:				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19. Fire Control Room:				
A	Detector system panel	Required	Provided	MR
B	Flow switch panel	NA	NA	NA
C	PA system panel	Required	Provided	MR
D	Battery backup	Required	Provided	MR
E	Building floor plans	NA	NA	NA
20. Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA



The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/NDZ/2021/01 dated 05/02/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


 16/2/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (LN)

Dy. CFO (NDZ) 
 19/02/24

C.F.O. 
 20/2/2024
 Director 
 20/2/24

F.T Letter is put up for sign. Please
 Director 
 23/2/24
 nsey

 22/2/2024