



FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School located at Rani Garden, Delhi-110031 owned/occupied by Govt. Girls Sr. Sec. School, comprised of ground plus two upper floors was issued FSC vide letter No. F6/DFS/MS/School/2017/NDZ/1760 dated 08/12/2017. The School building was re-inspected by the officer concerned of this department on 16/02/2024 in presence of Mr. Rajan Kumar (Principal) & Mrs. Poonam (H.O.S.) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building" (Group-B) with effect from 22/02/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 22/02/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Principal (Boys), Govt. Girls Sec. School, Rani Garden, Delhi-110031.
2. The Principal, Govt. Girls Sec. School, Rani Garden, Delhi-110031.
3. The Joint Director of Education, (Land & Estate), Director of Education, Lucknow Road, Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Govt. Girls Sr. Sec. School located at Rani Garden, Delhi-110031.		
02.	Building is comprised of	Ground plus two upper floors		
03.	Type of occupancy	Group B - Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2017/NDZ/1760 dated 08/12/2017.		
06.	Fire safety directives letter no.	Delhi Fire Service Act 2007 and Rule 2010.		
07.	Date of inspection	16/02/2024.		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mr.Rajan Kumar (Principal) & Mrs. Poonam (H.O.S.)		
10.	Year of construction	1978		
11.	Applicant's letter no.	Outdoor dairy no.11942 dated 16/01/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A	Road width	6.0 mtrs.	6.0 mtrs. ✓ MR
	B	Gate width	NA	NA NA
	C	Width of internal road	NA	NA NA
02.	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	02 nos. 02 nos. ✓ MR
		b	Basement	NA NA NA
	B	Width of staircases		
		a	Upper floor	1.50 mtrs. 1.40 mtrs & 1.35 mtrs. ✓ MR (Old accepted)
		b	Basement	NA NA NA
	C	Protection of exits		
		a	Fire check door	NA NA NA
		b	Pressurization	NA NA NA
	D	No. of continuous staircases to terrace		
		E	Width of corridor	1.50 mtrs. 2.40 mtrs. ✓ MR
		F	Door size	01 mtrs 01 mtrs ✓ MR
03.	Compartmentation:			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	NA	NA NA
	C	Fire rating of shaft door	NA	NA NA
	D	Water curtain	NA	NA NA
	E	Fire dampers	NA	NA NA
04.	Smoke Management System:			
	A	Basement	NA	NA NA
	B	Upper floor	NA	NA NA


(u)

05. Fire Extinguisher:				
	A	Total numbers	21 nos.	Provided ✓ MR
	B	Types	ABC/CO ₂	ABC/CO ₂ MR
	C	ISI marking	ISI Marked	ISI Marked MR
06. First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 no.	02 no. ✓ MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs. MR
	C	Nozzle diameter	05 mm	05 mm MR
07. Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA NA
	B	Location of main panel	NA	NA NA
	C	Location of repeater panel	NA	NA NA
	D	Alternate source of power	NA	NA NA
	E	Hooters	NA	NA NA
08. MOEFA:			NA	NA NA
09. Public Address System:			NA	Provided ✓ MR
10. Automatic Sprinkler System:				
	A	Basement	NA	NA NA
	B	Upper floor	NA	NA NA
	C	Sprinkler above false ceiling	NA	NA NA
11. Internal Hydrants:				
	A	Size of riser/down-comer	NA	100 mm ✓ NA
	B	Number of hydrants per floor	NA	01 no. NA
	C	Hose box	NA	01 no. NA
12. Yard Hydrants:				
	A	Total number of hydrants	NA	NA NA
	B	Hose box	NA	NA NA
13. Pumping Arrangements:				
1	Ground level			
	A	Discharge of main pump	NA	NA NA
	B	Head of main pump	NA	NA NA
	C	Number of main pumps	NA	NA NA
	D	Jockey pump out put	NA	NA NA
	E	Jockey pump head	NA	NA NA
	F	Standby pump out put	NA	NA NA
	G	Standby pump head	NA	NA NA
	H	Auto starting /manual stopping	NA	NA NA
	I	Pump house access	NA	NA NA
2	Terrace Level			
	A	Discharge of pump	450 LPM	450 LPM X ✓ MR 02 nos.
	B	Head of the pump	40 mtrs.	40 mtrs. MR
	C	Power supply	Required	Provided MR
	D	Auto starting of pump	Required	Provided MR

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	10,000 liters.	10,000 liters.	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17. Standby Power Supply:		NA	NA	NA
18. Refuge Area:				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19. Fire Control Room:				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20. Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA


The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F.6/DFS/MS/School/2023/NDZ/129 dated 20.03.2023 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 262-362 dated 17.01.2005, the FSC issued vide letter no. F6/DFS/MS/School/2017/NDZ/1760 dated 08/12/2017 is recommended to be renewed.


16/2/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~Dy. CFO (NDZ)~~
~~C.F.O.~~
~~20/2/2024~~
~~Director~~
~~20/2/2024~~

F.T letter is setup for sign. Please
Director 
2/2/2024