

C44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/134

Dated: 23/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sr. Sec. School, Sector-3, Rohini, Delhi-110085. School ID-1413002, comprised of Ground and 03 upper floors owned/occupied by Govt. Sr. Sec. School has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2021/133 Dated 17.02.2021. The premises was re-inspected by the officer concerned of this department on 13.02.2024 in the presence of Mr. O. P. Meena (In-charge) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy under Educational "Group B" with effect from 23/02/2024 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/02/2024 at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:

1. The Principal, Govt. Sr. Sec. School, Sector-3, Rohini, Delhi-110085. School ID-1413002.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Govt. Sr. Sec. School, Sector-3, Rohini, Delhi-110085. School ID-1413002.
2. Type of Occupancy	Educational
3. Type of Case	Renewal (Single Block, Ground + 03 upper floors)
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/133 dated 17.02.2021.
5. Fire Safety directives letter No	NBC Part-IV
6. Date of inspection	13.02.2024.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. O. P. Meena (In-charge)
9. Year of Construction	2017
10. Applicant's letter No.	OD No.12858 dated 08.02.2024.


S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	6.0m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	03nos.	03nos.	MR
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases			
	• Upper Floor	1.5m	2 x 2.0m & 1.15m	MR(Old case)
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	Natural ventilated	Provided	MR
	d. No. of continuous staircases to terrace	02nos.	02nos.	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	f) Fire check door	-NA-	-NA-	-NA-
	g) Sealing of electrical shafts	-NA-	-NA-	-NA-
	h) Fire Rating of shaft door	-NA-	-NA-	-NA-
	i) Water Curtain	-NA-	-NA-	-NA-
	j) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	c) Basements	-NA-	-NA-	-NA-
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	d) Total numbers	40ns.	60nos.	MR
	e) Types	ABC/CO2	ABC-30/CO2-30	MR
	f) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	d) Total numbers on each floor	03	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR
	f) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			

	f) Type of detectors	-NA-	-NA-	-NA-
	g) Location of Main Panel	-NA-	-NA-	-NA-
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	d) Basement	-NA-	-NA-	-NA-
	e) Ground & Upper Floors	-NA-	-NA-	-NA-
	f) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	d) Size of riser/down-comer	-NA-	100mm	-NA-
	e) Number of hydrants per floor	-NA-	03nos.	-NA-
	f) Hose Box	-NA-	03nos.	-NA-
12.	Yard Hydrants			
	c) Total number of hydrants	-NA-	06nos.	-NA-
	d) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	100,000ltr	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	f) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	g) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	h) Communication In lift Car	-NA-	-NA-	-NA-
	i) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	j) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			

c) Total Area	-NA-	-NA-	-NA-
d) Location	-NA-	-NA-	-NA-
Fire Control Room			
f) Detector System Panel	-NA-	-NA-	-NA-
g) Flow Switch Panel	-NA-	-NA-	-NA-
h) PA System Panel	-NA-	-NA-	-NA-
i) Battery backup	-NA-	-NA-	-NA-
j) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 30 dated 24.01.2024, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2021/133 Dated 17.02.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

Dy. CFO(WZ)



16/2

695
16/2/2024


Director
19/1/24



FI letter to put up for kind perusal and signature please.


Director
21/2/24
M


21/2/24