

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. D6/DFS/MS/SZ/2024/School/124

Dated: 21/02/2024

FIRE SAFETY CERTIFICATE

Certified that the building of MCD Primary School Located at village Nasirpur, New Delhi – 110045, having 03 blocks comprised of Two Block-Ground floors and One Block-Ground + 1 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/SZ/2021/142, dated: 19/02/2021. (Issued for two blocks - ground floor & G+1UF) The premises was re inspected by the officer concerned of this department on 12/02/2023 in the presence of Ms. Sunita Goel (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 17-01-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 21/02/2024 for a period of three years.

Issued on 21/02/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service
21/02/24

Copy to:

1. The Principal, MCD Primary School at village Nasirpur, New Delhi – 110045.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/17

INSPECTION REPORT

1. Name & address of the building: MCD Primary School Located at village Nasirpur, New Delhi - 110045.
2. Type of Occupancy : Educational Building (03 blocks- Two Block-Ground floor & One Block-G+ 1 UF)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/142, dated:19/02/2021
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 12-02-2024
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Ms. Sunita Goel Principal)
9. Year of Construction : 2006
10. Applicant's letter No. :Form J dated 05/02/2024

No. of Students=1224
No. of class rooms=27
Plot area=8125sq.m
Covered area =3610sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10, N/11 & N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtr	6mtrs	MR
	• Gate width	4.5m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	Provided	MR
	• Basements	N/A	N/A	NA
	b. Width of staircases			
	• Upper floors	1.5mtr&75cm	1.5m & 1.25m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	07 nos.	10 Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

N/19

		Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/142, dated:19/02/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: Earlier FSC was issued for two blocks comprised of ground & ground plus one upper floor.

Signature of the Inspecting Office
Name Uday Singh
Designation ASO/MS

DO/SO
16/2/24
CFO/(SZ)
16/2/2024
Director
16/2/24
16/2/24
16/2/24

A/P

Any one