

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/57

Dated. 22/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & Style of **M/s Depot 48** located at **M-9, First & Second floor**, M Block Market, GK-II, New Delhi -110048 in the building comprised of Basement, Ground plus Three upper floor owned/occupied by Unit of Glocal Foods was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2020/SZ/120 dated 05/10/2020. The restaurant premise was re-inspected by the officer concerned of this department on 14/02/2024 in the presence of Mr. Vikas Narula and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant running at 1st & 2nd Floor only)** and validity upto 31/03/2027 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/02/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-110016 (Ref. MHA Portal ID 2024013000991 dated 31/01/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/24

INSPECTION REPORT

1	Name & Address of the Building	M/s DEPOT 48, (Unit of GLOCAL Foods) at M-9, 1 st & 2 nd Floor, M Block Market, GK-2, New Delhi 110048		
2	Type of Occupancy	Assembly Building "Group-D"		
3	Building Comprised of	Basement, Ground + 02 upper floors (Restt. at 1 st & 2 nd Floor)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2020/SZ/120 dated 05/10/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14/02/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Vikas Narula		
10	Year of construction	1990		
11	Applicant letter No.	MHA Portal ID 2024013000991 dated 31/01/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL 2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	Provided	MR
	• Gate width	Abuts on road	Approachable	MR
	• Width of internal road	NA	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 Nos	MR
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	1.25 m & 0.75 m	0.95 m & 0.67 m	MR (old case)
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.0m	1m & 0.93 mtr	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Nos.	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	2 nd floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A



N/25

	<ul style="list-style-type: none"> • Alternate source of power • Hooter's location 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 	100 mm	Provided	MR
		01 Nos	Provided	MR
		01 Nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. • 2. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting / Manual Stopping. ➤ Access to pump house • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	2280 LPM	Provided	MR
		60m	Provided	MR
		01 No	Provided	MR
		180 LPM	Provided	MR
		60m	Provided	MR
		2280 LPM	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	1,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		5,000 ltr	20,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A


2

✓

2/9/24


20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 687 dated 27/12/2023 and the management submitted an affidavit that the restaurant M/s Depot 48, located at M-9, M Block Market, GK-2 New Delhi running at 1st & 2nd Floor only.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2020/SZ/120 dated 05/10/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <div style="display: flex; justify-content: space-between; margin-top: 20px;"> <div data-bbox="207 604 622 806"> <p> Signature of the Inspection Officer Name: Sh. Manoj Kumar Sharma Design: DO (South)</p> </div> <div data-bbox="909 593 1324 806"> <p> Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p> </div> </div>				

CFO (HQ)

through
19/21/2024
Director 
19/21/24

ADO/BCP

As approved, F.T. letter is put up for
your signature pl

Director 
21/1/24


21/1/24

JKR

Uploaded
23/6/24
