

c/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F6/DFS/MS/School/WZ/2024/ 135

Dated: 26/02/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Shri Motinath Sanskrit Mahavidyalaya located at Ramesh Nagar, New Delhi-110015. (School ID-1516082), comprised of Ground + One upper floor only. Owned /Occupied by Shri Motinath Sanskrit Mahavidyalaya, was already issued FSC vide letter No. F6/DFS/MS/School/2020/WZ/457 dated 04/11/2020. The premises was re-inspected by the officer concerned of this department on 19/02/2024 in the presence of Sh. Pardeep Kumar and observed that all the fire prevention and fire safety arrangements provided in the Premises/building found in good working condition. The said building/Premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F6/Estate/CC/Fire/safety/2011/3298-3398 dated 01/03/2011 issued by the Directorate of Education and found that the premises is fit for occupancy class "Educational" (Group- B) with effect from 26/02/2024 for a period of three years, subject to compliance of the conditions mentioned below.

Issued on 26/02/2024 at New Delhi.


(Atul Garg)
Director

Copy to:

1. The Principal/H.O.S., Shri Motinath Sanskrit Mahavidyalaya located at Ramesh Nagar, New Delhi-110015. (School ID-1516082)
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.


23/02/2024

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. If Rooms on terrace are opened/used, then Fire safety Certificate will be treated null & void.

INSPECTION REPORT

1. Name & address of the building		Shri Motinath Sanskrit Mahavidyalaya, Located at Ramesh Nagar, New Delhi-110015. (School ID-1516082)		
2. Type of Occupancy		Educational (Ground + 1)		
3. Type of Case		Renewal		
4. Details of previous NOC		F6/DFS/MS/School/2020/WZ/457 dated 04/11/2020		
5. Fire Safety directives letter No		DOE Circular NO -3298-3398 dated 01/03/2011		
6. Date of inspection		19/02/2024		
7. Name of the Inspecting Officers		Sarabjeet Singh, ADO (MN)		
8. Name and designation of officers from the building side		Sh. Pardeep Kumar		
9. Year of Construction		1990 (As per previous inspection report Dated – 26/10/2020)		
10. Applicant's letter No.		Letter No.- MNS/1436 dated 15/09/2023		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02 Provided	MR(Old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.20 X2 Provided	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	1.77m, 0.80cms Provided	MR
	g. Door Size	1 m	1.0m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level		NA	
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA
17	Standby power supply	NA	NA
18	Refuge Area.		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Batter backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

DD/MNP
2/2/24

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/School/2020/WZ/457 dated 04/11/2020 renewal under DOE 3298-3398 dated 01/03/2011 is recommended.

(Signature)
2/2/24

(Signature)
2/2/24
Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN)

(Signature)
2/2/24

87
2/2/24

(Signature)
2/2/24

(Signature)
2/2/24

(Signature)

Sir, F. T is put up for your kind personal & signature please.