



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-
आजादी
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/145

Dated:- 27/02/2024

FIRE SAFETY CERTIFICATE

Certified that the Indraprastha World School, Located at A-2, Block, Paschim Vihar, New Delhi-110063 comprised of Ground + 03 Upper Floors only owned/occupied by Indraprastha World School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2020/WZ/246 Dated 27.07.2020. The said premise was re-inspected by the officer concerned of this department on 20/02/2024 in the presence of Sh. Bhagwant Singh (Office Superintendent) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 27/02/2024 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 27/02/2024.... at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Indraprastha World School, A-2, Block, Paschim Vihar, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. All the means of escape leading ground to terrace shall always be kept unlocked & free of all type of obstruction all the time. If, it is found locked during emergency the management will be held responsible.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. Temporary inspection ladder may be provided during the inspection of fire over-head-tank to check the level of water.

INSPECTION REPORT

1. Name and address of the building: **Indraprastha World School, Located at A-2 Block, Paschim Vihar, New Delhi-110063.**
2. Type of Occupancy : Educational, (Ground + 03 Upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/WZ/246 Dated 27.07.2020
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17.01.2005
6. Date of inspection : 20/02/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Bhagwant Singh (Office Superintendent)
9. Year of Construction : 2006
10. Applicant's letter No. : email dated 09/02/2024
: letter no. IPWS/MN/Renew/DFS/200224/03 dated 20/02/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E Cr. No. 262-362 dated 17.01.2005/as per FSC dated 27.07.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	06 m	MR
	• Gate width	Accessible	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.4 m x 3 & 1.10 m x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m (Class Room) 1.5 m x 2 (Audi)	1 m x 1 (Class room) 1.7 m x 1, 1.6 m x 1, 1.10 m x 1 (Audi)	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR

5.	Fire Extinguishers			
	• Total numbers	18 nos.	20 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground Floor	Required (Auditorium)	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 each floor	Provided	MR
	• Hose Box	01 each floor	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm (Main Pump)	900 lpm Provided	MR
		225 lpm (Jocky Pump)	225 lpm Provided	
		450 lpm (For Sprinkler in Audi.)	450 lpm (For Sprinkler in Audi.) Provided	
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltrs. (Sprinkler System in Audi at GF)	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	13,000 ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	> Pressurization of Lift Shaft	NA	NA	NA
	> Pressurization of lift lobby	NA	NA	NA
	> Communication in lift Car	Required	Provided	MR
	> Fireman's Grounding Switch	Required	Provided	MR
	> Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any,	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/WZ/2023/School/322 dated 09/08/2023 are rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17/01/2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2020/WZ/246 Dated 27.07.2020 is recommended.

Accordingly DFA is put up for approval please.

Q111H 11
23/12/24
Aman Kumar Lathar
ADO (JWP)

CCFO (WZ)
22/12/24
23/12/24
CFO
26/12/2024
Director
26/12/24
Aman Kumar Lathar

Sir, F.T. letter is put-up for your signature H.

Director
27/12/24
Aman Kumar Lathar
Q111H 11
27/12/24
Aman Kumar Lathar