

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 129

Dated: 01/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Multipurpose Community hall Located at HAF, Pocket-C, Sector - 16B, Dwarka, New Delhi, comprised of Basement+ Stilt /Ground + 3 Upper Floors owned/occupied by DDA have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 28/02/2024 in the presence of Mr. Rajeev Gupta, Neeraj Kumar (EE DDA) & Sh Alok Prakesh (AE DDA) and found that the said premises is fit for occupancy class 'D' "Assembly Building" (Community Hall) with effect from 01/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...01.03.2024.....at New Delhi by.

  
(Atul Garg)

Director,  
Delhi Fire Service.

Copy to:

1. The Executive Engineer (E)/ELD-5/DDA, Delhi Development Authority, Electrical Division-5, Central Nursery, Sector -5 Dwarka, New Delhi-110075.
2. The Chief Engineer (Dwarka) / DDA, Manglapuri, Delhi.

**Following fire safety directives must be adhered to:-**

1. The FSC shall be null and void if the 6 meter road not cleared/provided within 6 months.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Multipurpose Community hall Located at HAF, Pocket-C, Sector - 16B, Dwarka, New Delhi.
2. Type of Occupancy : Assembly (B+S/G + 3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2015/12, dated 14/01/15
6. Date of inspection : 28/02/2024
7. Name of the Inspecting Officer : ADO/DWK
8. Name and designation of Officer  
from the building side : Mr. Rajiv Gupta (EE DDA) & Alok Parkesh (AE DDA)
9. Year of Construction : 2016
10. Applicant's letter No. : Ex. Engr./Elec. Div-5/DDA/W-42/764, dated 2702/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6m	5.8 to 6m ( The width shall be increased with in 6 month) Undertaking submitted	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2 m	Provided	MR
	• Basements	1.5m	180m to 2m & 2.4m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m	2m & 1.5m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	As per IS-2190/1992.	Provided	MR
	• Types	Water & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 Required	01 Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	40 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	40 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	40 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	900 lpm	NA
	➤ Head of the pump	NA	40 m	NA
	➤ Power supply	NA	Provided	NA
	➤ Auto starting of pump	NA	Provided	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	75000 litres	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR

4/9

List of Lifts Not Installed/ commissioned till now			
	Pressurization of Lift Shaft	....	....
	Pressurization of lift lobby	....	....
	Communication in lift Car	....	....
	Fireman's Grounding Switch	....	....
	Lift Signage	....	....
17.	Standby power supply	Required	provided MR
18.	Refuge Area		
	➤ Total area	NA	NA NA
	➤ Location	NA	NA NA
19.	Fire control room		
	➤ Detector system panel	Required	Provided MR
	➤ Flow Switch Panel	Required	provided MR
	➤ PA System Panel	Required	provided MR
	➤ Battery backup	Required	Provided MR
	➤ Building Floor Plans	Required	Provided MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

**Note:-** Vide letter No. Ex. Engr./Elec. Div-5/DDA/W-42/764, dated 2702/2024 undertaking has been submitted by EE(E), DDA that the 6meter road around the building shall be provided within 6months.

Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation 4100/2017

DP/SW 28/2/24

CF/S2 28/2/24

Director 25/2/24

DP/SW NKU