

No. F6/DFS/MS/School/SZ/2024/169

Dated: 05.03.2024

FIRE SAFETY CERTIFICATE

Certified that the Andhra Education Society Senior Secondary School, Prasad Nagar, New Delhi-110059, comprises of ground plus three upper floors, owned/occupied by Andhra Education Society have complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398, Dated 01.03.2011 and verified by the officer concerned of this department on 27-1-2024 in the presence of Sh. Venu Gopal, Teacher of the school and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class B 'Educational Building' with effect from ..05/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions mentioned below.

Issued on 05 .03.2024 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Andhra Education Society Senior Secondary School, Prasad Nagar, New Delhi-110059.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this FSC to Director in Form 'J' [Sub Rule (1) of Rule 37] alongwith a copy of this certificate, six month prior to its expiry.

N/11

INSPECTION REPORT

1. Name & address of the building : Andhra Education Society Senior Secondary School, Prasad Nagar, New Delhi-110005.
2. Building is comprised of : G+3.
3. Type of Occupancy : Education
4. Type of Case : New
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 27.02.2024.
8. Name of the Inspecting Officers: : Vedpal Chhikara(DO-SW)
9. Name and designation of Officer from the building side : Sh. Venu Gopal, Teacher of the school.
10. Year of Construction : 1999
11. Applicant's letter No : No. AESPN/GEN/FIRE/2023-24/617, dated 23.01.2024

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per DoE Circular dt 01.03.2011	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	Provided	MR
	Gate width	4.5m	Provided	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	2nos.	2nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.50m or less & 0.75m	1.68m & 1.35m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	1no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural Vent.	MR
5.	Fire Extinguisher			
	Total numbers	10nos.	10 nos.	MR
	types	CO ₂ & ABC	ABC Type	MR
	ISI marking	ISI marked	ISI marked	MR

64

N/12

6	First-aid-Hose Reels.	01no.	01no.	MR.
	Total numbers of each floor	30m	30m	MR.
	Length of hose reel hose	5mm	5mm	MR.
	Nozzle diameter			
7	Automatic fire detection and alarming system.	N.A.	N.A.	N.A.
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	01no.	01no.	MR.
	➤ Head of the Pump	450LPM	Provided	MR
	➤ Power supply	40m	40m	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000 liters	10000 liters	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.
	Communication in lift car	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.
	Lift Signage	N.A.	N.A.
17	Standby power supply	Required	Provided
18	Refuge Area.	Required	MR
	Total area	N.A.	N.A.
	Location	N.A.	N.A.
19	Fire Control Room	N.A.	N.A.
	Detector system panel	N.A.	N.A.
	Flow switch panel	N.A.	N.A.
	PA system panel	N.A.	N.A.
	Batter backup	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	02 ABC type fire extinguishers provided near elect. panel

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety systems required under Director of Education circular No.3298-3398 dated 1.03.2013. It is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

Accordingly, DFA is put up for kind approval please.

Signature of the Inspecting Officer
Name Vedpal Chhikara
Designation DO(SW)

CFP(SZ)
28/11/2014
Director
20/12/14
DHSW

FT letter is put up for sign pl
4/3/24
D.O (S.W)
DIRECTOR/DES
20/12/14