



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2024/64

Dated: 04 / 03 / 2024

FIRE SAFETY CERTIFICATE

Certified that the Gol sports & Bar (A Unit of E Hotelier and Company) located at TF-02A, Third Floor City Square Mall, Raja Garden, Rajouri Garden, New Delhi-110027, running at third floor in city Square mall Rajouri Garden comprised of 02 Basement + Ground + 04 Upper Floor was issued FSC to mall vide this department letter no. F6/DFS/MS/WZ/Mall/2023/473 dated 05/10/2023. The building/premises was re-inspected by the officer concerned of this department on 21/02/2024 in the presence of Sh. Surender Dabas (Director) and found that the said premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) & valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on 04/03/2024... at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The owner/occupier, Gol sports & Bar (A Unit of E Hotelier and Company) located at TF-02A, Third Floor, City Square Mall, Raja Garden, Rajouri Garden, New Delhi-110027. **Online Application ID no. 2024020701352 dated 07/02/2024**
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in.)
3. The Dy. Health Officer, West Zone, MCD, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhwestzone@gmail.com)

INSPECTION REPORT

1. Name & address of the building	Gol sports & Bar (A Unit of E Hotelier and Company) Located at TF- 02A, Third Floor City Square Mall, Raja Garden, Rajouri Garden, New Delhi-110027.			
2. Type of Occupancy	Eating House /Assembly Occupancy			
3. Type of Case	Renewal			
4. Details of previous NOC	F6/DFS/MS/EH/2018/WZ/2441 dated 31/10/2018			
5. Fire Safety directives letter No	Nil			
6. Date of inspection	21/02/2024			
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)			
8. Name and designation of officers from the building side	Sh. Surender Dabas (Director)			
9. Year of Construction	2005 (As per MHA Portal)			
10. Applicant's letter No.	Online Application ID No. 2024020701352 dated 07/02/2024			
<p>The said restaurant is running at Third floor in City Square Mall, building comprised of 02 Basement + Ground + 04 upper floors was issued FSC vide letter no. F6/DFS/MS/WZ/Mall/2023/473 dated 05/10/2023</p>				
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 m	Provided	MR
	• Gate width	06 m	Provided	MR
	• Width of internal road	06 m	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Required	06 Provided by mall	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtr each	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	03	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 m x 1,1m X 1	Provided	MR
3	Compartmentation. (For Mall)			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	04 Hours	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	04	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels. Common with the Mall			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system. Common with the Mall			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Ground Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System. Common with the Mall			
	• Basement	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants Common with the Mall			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements. Common with the Mall			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Common with the mall	MR
	➤ Head of the pump	40 mts	Common with the mall	MR
	➤ Power Supply	Required	Common with the mall	MR
	➤ Auto Starting of pump	Required	Common with the mall	MR
14	Captive Water Storage for fire fighting. Common with the Mall			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	20,000 ltrs	Common with the mall	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

49/ADD/MN
26/02/2024

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on Fire Prevention and fire safety required under the rules the NOC issued vide letter no.- F6/DFS/MS/WZ/2020/286 dated 31/07/2020 renewal under rule 35 of the Delhi Fire service Rules 2010 is recommended.

By CND 60/20

[Signature]
26/02/2024
Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

DCFO/183-MHA..
Dated..27/02/24..

[Signature] 27/2/2024
As per drawing bath exit are side by side. (c.c. 42)
[Signature] 28/2/2024

Director *[Signature]* 29/2/24

This is end of record,
I thank 3rd record, your
renewal. your commits
[Signature] 29/2/24

Agree & also will be take care in other cases
(if any)
Director *[Signature]* 29/2/24