



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/171

Dated:- 05/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Rajkiya Pratibha Vikas Vidyalaya (School ID-1617009)**, Located at **A-6, Paschim Vihar, New Delhi-110063**, comprised of **Ground + 03 Upper Floors & M.P. Hall at 2<sup>nd</sup> Floor only** owned/occupied by **Rajkiya Pratibha Vikas Vidyalaya (School ID-1617009)** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on **22/02/2024** in the presence of **Sh. Diwan (Contractor Supervisor)** and that the building/premises is fit for occupancy class "**Educational Building**" **Group B** with effect from **05/03/2024** for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.


Issued on **05/03/2024** at New Delhi by.

  
(Atul Garg)  
Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054
2. The Assistant Engineer (E), Edu. Sub-Divn M1-1, (N), PWD, ITI Campus, Pusa, New Delhi-110012.
3. The Principal, Rajkiya Pratibha Vikas Vidyalaya (School ID-1617009), A-6, Paschim Vihar, New Delhi-110063.

  
05/03/24

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

# INSPECTION REPORT

21

1. Name & address of the building: **Rajkiya Pratibha Vikas Vidyalaya**  
(School ID-1617009) located at **Block A-6, Paschim Vihar, Delhi**
2. Type of Occupancy : Educational,
3. Type of Case : New, (G + 03 Upper Floors) & M.P. Hall at 2<sup>nd</sup> Floor (Double Floor Height)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : as per NBC Part-IV
6. Date of inspection : 22/02/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Diwan (Contractor Supervisor)
9. Year of Construction : 2022-23
10. Applicant's letter No. : email dated 20/01/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	06	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04	06	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.2 m & 2 m	1.2 m (class room) 2 m x 4 (M.P Hall)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Openable Windows	MR
5.	Fire Extinguishers			
	• Total numbers	30 nos.	50 nos.	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	04	06	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm x 2 450 lpm x 2	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs + 10,000 ltrs.	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA

	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - The School Management has constructed a M. P. Hall at 2<sup>nd</sup> floor (Double Floor Height 2<sup>nd</sup> & 3<sup>rd</sup>), have provided 04 nos. exit doors (2 m x 4).

Keeping in view substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under Rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

*[Signature]*  
23/02/24  
Aman Kumar Lathar  
ADO (JWP)

*[Signature]*  
23/02/24

*[Signature]*  
23/02/2024

154-W  
23/02/24

*[Signature]*  
26/2/2024  
Director  
*[Signature]*  
26/2/24

*[Signature]*

Sir, R.F. letter is put-up for your signature pl.

*[Signature]*  
Director  
*[Signature]*  
m

*[Signature]*  
05/03/24  
Aman QWP