

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2024/School/WZ/168

Dated: 05/03/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sunny Convent School, A-57-58, Suraj Park, (Opp. Badli Indl. Area), Near Badli Telephone Exchange, Badli, Delhi-110042**, comprised of **Ground + 02 upper floors** owned/occupied by **Sunny Convent School** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2021/151 dated 23.02.2021**. The premises was re-inspected by the officer concerned of this department on **23.02.2024** in the presence of **Smt. Dimple Singh (Head-Mistress)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 05/03/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 05/03/2024 at New Delhi

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Sunny Convent School, A-57-58, Suraj Park, (Opp. Badli Indl. Area), Near Badli Telephone Exchange, Badli, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT				
1. Name & address of the building	Sunny Convent School, A-57-58, Suraj Park, (Opp. Badli Indl. Area), Near Badli Telephone Exchange, Badli, Delhi-110042.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Ground + 02 upper floors)			
4. Details of Previous NOC	F.6/DFS/Ms/School/WZ/2021/151 dated 23.02.2021			
5. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.			
6. Date of inspection	23.02.2024.			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Smt. Dimple Singh (Head- - Mistress)			
9. Year of Construction	1996			
10. Applicant's letter No.	Online e-mail dated 22.01.2024			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Direct accessible from road	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.0m & 1.12m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	01nos.	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	Required	1.0m	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	07nos.	07nos.	MR
	b) Types	ABC/CO2	ABC-07nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR

4


				Ref	a	b
7.	Automatic fire detection and alarming system					
	a) Type of detectors	-NA-	-NA-	-NA-		
	b) Location of Main Panel	-NA-	-NA-	-NA-		
	c) Location of Repeater Panel	-NA-	-NA-	-NA-		
	d) Alternate source of power	-NA-	-NA-	-NA-		
	e) Hooters' Location	-NA-	-NA-	-NA-		
8.	MOEFA					
9.	Public Address System					
10.	Automatic Sprinkler System					
	a) Basement	-NA-	-NA-	-NA-		
	b) Ground & Upper Floors	-NA-	-NA-	-NA-		
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-		
11.	Internal Hydrants					
	a) Size of riser/down-comer	-NA-	-NA-	-NA-		
	b) Number of hydrants per floor	-NA-	-NA-	-NA-		
	c) Hose Box	-NA-	-NA-	-NA-		
12.	Yard Hydrants					
	a) Total number of hydrants	-NA-	-NA-	-NA-		
	b) Hose Box	-NA-	-NA-	-NA-		
13.	Pumping Arrangements					
	• Ground Level	-NA-	-NA-	-NA-		
	➤ Discharge of main Pump	-NA-	-NA-	-NA-		
	➤ Head of Main pump	-NA-	-NA-	-NA-		
	➤ Number of main pumps	-NA-	-NA-	-NA-		
	➤ Jockey Pump out put	-NA-	-NA-	-NA-		
	➤ Jockey pump head	-NA-	-NA-	-NA-		
	➤ Standby Pump out put	-NA-	-NA-	-NA-		
	➤ Standby Pump Head	-NA-	-NA-	-NA-		
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-		
	➤ Pump House Access	-NA-	-NA-	-NA-		
	Terrace level					
	➤ Discharge of pump	450lpm	450lpm	MR		
	➤ Head of the pump	40m	40m	MR		
	➤ Power Supply	Required	Provided	MR		
	➤ Auto Starting of pump	Required	Provided	MR		
14.	Captive Water Storage for fire fighting					
	• Underground tank capacity	-NA-	-NA-	-NA-		
	➤ Draw-off connection	-NA-	-NA-	-NA-		
	➤ Fire service inlet	-NA-	-NA-	-NA-		
	➤ Access to tank	-NA-	-NA-	-NA-		
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR		
15.	Exit Signage.	Required	Provided	MR		
16.	Provision of Lifts.					
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-		
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-		
	c) Communication In lift Car	-NA-	-NA-	-NA-		
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-		
	e) Lift Signage	-NA-	-NA-	-NA-		
17.	Standby power supply					

my

18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/Ms/School/WZ/2021/151** dated **23.02.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

Dy. CFO(WZ)



28/2

CFO/603-NK.....

Dated 28/02/24... CFO


29/2/2024

Director


11/3/24

ADY Rohini

Fr letter is put up for kind. perusal and
Signature please.


11/3/24

