



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/CNG/SZ/2024/146

Dated: 08/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s CNG Filling Station located at 4, Raj Road behind Safdarjung Hospital, Ring Road, New Delhi, comprised of ground floor only having 03 Compressor 04 Cascades & 11 nos dispensing units was issued FSC by this department vide letter No. F.6/DFS/MS/2021/CNG/SZ/138 dated 23/02/2021. The premises was re-inspected by the officer concerned of this department on 02/03/2024 in the presence of Mr. Rahul Kirar (Dy. Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with OISD-179/ rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Hazardous** (CNG Pump) with effect from 08/03/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 08/03/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. Sh. Ajay Khatri, General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

### INSPECTION REPORT

1	Name & Address of the Building	CNG Filling Station at 4, Raj Road behind Safdarjung Hospital, Ring Road, New Delhi.		
2	Type of Occupancy	Hazardous (CNG Pump)		
3	Building Comprised of	Ground floor only (03 Compressor, 04 Cascades & 11nos dispensing units)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2021/CNG/138 dated 23/02/2021		
6	Fire Safety Directives Letter No	OISD-179/F.6/DFS/MS/CNG/2019/1484 dated 26/03/2019		
7	Date of Inspection	02/03/2024		
8	Name of the Inspecting Officers	Santosh Kumar (ADO/SJ)		
9	Name & Designation of Officers from the building side	Mr. Kunal Bansal (Manager)		
10	Year of construction	2018		
11	Applicant letter No.	Outdoor Diary No. 13440 dated 22/02/2024		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Requirements/ Existing Fire Protection System</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	6m	Provided	MR
	• Gate width	4.5mtr	6m	MR
	• Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	NA	NA	NA
	➤ Basement.	NA	NA	NA
	<b>b) Width of Staircase</b>			
	➤ Upper floors	NA	NA	NA
	➤ Basement	NA	NA	NA
	<b>c) Protection of exits</b>			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	<b>d) No. of continuous staircase to terrace</b>	NA	NA	NA
	<b>e) Width of corridor</b>	NA	NA	NA
	<b>f) Door size</b>	NA	NA	NA
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	15nos	24nos	MR
	• Types	CO <sub>2</sub> & DCP	DCP (10kg)-10, DCP (75kg)-09, CO <sub>2</sub> (4.5kg)-02 & Water Mist Trolley-01	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA


7.	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Gas & Flame	Gas & flame & hand-held gas detector	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>CO<sub>2</sub> Flooding System</b>			
	<ul style="list-style-type: none"> <li>Ground floor</li> <li>Upper floors.</li> <li>Sprinkler above false ceiling</li> </ul>	Required in compressors	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	<b>Captive water storage for Fire Fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	<b>No Smoking Signage (Hindi &amp; English)</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA

<b>19.</b>	<b>Fire Control Room.</b>			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
<b>20.</b>	Special Fire Protection System for the Protection of special Risk, if any.	Fire buckets filled with sand. No smoking boards & emergency no. displayed in Hindi & English. No loose electric wiring, 6' high boundary wall with barbed wire provided		
				MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/2021/CNG/SZ/138 dated 23/02/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (SJ)

DO (SD)


Mull  
05/07/21

Cfo Thugh  
6/07/21  
Director 6/07/21

ADU/SJ  
KIM

Sir, F.T letter is put up for your sign, pl

Director  
8/07/21

  
08/07/21