



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/CNG/SZ/2024/148

Dated: 08 / 03 / 2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Indraprastha Gas Limited Retail Outlet (CNG Pump)** located at Shantipath, Chanakyapuri, New Delhi, comprised of ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/CNG/SZ/2021/238 dated 28/04/2021. The premises was re-inspected by the officer concerned of this department on 02/03/2024 in the presence of Sh. Rahul Kirar (Deputy Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with OISD-179/ rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Hazardous (CNG Pump)** with effect from 08/03/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 08/03/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
91/82

Copy to: -

1. Sh. Ajay Khatri, General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/S Indraprastha Gas Ltd. Retail Outlet (CNG Pump), Shantipath, Chanakyapuri, New Delhi		
2	Type of Occupancy	Hazardous (CNG Pump)		
3	Building Comprised of	Ground floor only (03 Cascades at roof of office bldg. 03 Compressor units & 06 dispensing units)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/CNG//SZ/2021/238 dt 28/04/2021		
6	Fire Safety Directives Letter No	F.5(3A)/DFS/CNG/2000/145 dated 29/03/2000		
7	Date of Inspection	02/03/2024		
8	Name of the Inspecting Officers	Santosh Kumar, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Rahul Kirar (Deputy Manager)		
10	Year of construction	2000		
11	Applicant letter No.	Outdoor Diary No. 13120 dated 14/02/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9m	12m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	01	MR
	➤ Basement.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	Required	0.70m	MR
	➤ Basement	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	20nos	22nos	MR
	• Types	CO ₂ & DCP	CO ₂ (4.5kg)-04 & DCP (75kg)-4, DCP (10kg)-14,	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

89


7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Gas & Flame	Provided in compressor	MR
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooter's location 	Required	Technician room	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground floor. 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of Hydrant per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose box. 	NA	NA	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	NA	NA	NA
	<ul style="list-style-type: none"> Hose box. 	NA	NA	NA
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of main pump. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump house access. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump house access. 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of pump. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power supply. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank. 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead tank capacity. 	NA	NA	NA
15.	No Smoking Signage (Hindi & English)	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift car. 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's switch. 	NA	NA	NA
	<ul style="list-style-type: none"> Lift signage. 	NA	NA	NA
17.	Standby Power Supply	NA	Provided	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA

19.	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Provided CO ₂ flooding system connected through detectors in each compressor	MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2021/CNG/212 dated 08/04/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 04.03.24
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)


DO (SD)

mm
spmm

cto Khushi
6/31/2024

Director [Signature]
AD(SJ)

F.T letter is put up for your signature PL


 08.03.24

Director [Signature]
[Signature]

m