

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/EH/62

Dated: 29/02/2024

FIRE SAFETY CERTIFICATE

Certified that the building **Foodlink, F and B Holdings India Pvt. Ltd.** Located at 2nd Floor ECC, Sector-25, Dwarka, Delhi, in a building comprised of 4 tier Basement + Ground + 08 Upper Floors, (Fire Safety Certificate issued to the ECC vide letter No. F6/DFS/MS/SZ/2023/428 dated 06/09/2023) owned/ occupied by **Foodlink F and B Holdings India Pvt. Ltd** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned from this department on 20/02/2024 in the presence of Sh. Rakesh Awasthe (Foodlink Representative) and found that the said premises is fit for occupancy class "Assembly" Group D (Second Floor) with effect from 29/02/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/02/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, Foodlink F and B Holdings India Pvt. Ltd. at 2nd Floor Exhibition Cum Convention Centre (ECC) located at, Sector-25, Dwarka, Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Foodlink, F and B Holdings India Pvt. Ltd.
Located at 2nd Floor, ECC, Sector-25, Dwarka, Delhi.
2. Type of Occupancy : Assembly at 2nd Floor (At ECC building comprised of 2B+G+8 UFs)
3. Type of Case : New
4. Details of previous NOC : Nil (F6/DFS/MS/SZ/2023/428, dated 06/09/2023, Issued to ECC building) (Whole Building)
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2018/194, dated 18/06/2018
6. Date of inspection : 20/02/2024
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Rakesh Awasthe (Foodlink Representative)
9. Year of Construction : 2019 to 2023
10. Applicant's letter No. : 2024012000661 dated 07/02/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC/UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	6 mtr	Provided	MR
	• Width of internal road	9 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	Provided	MR
	• Basements	NA	Provided	NA
	b. Width of staircases			
	• Upper floors	2 mtr	Provided	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	2 mtr	Provided	MR
	f. Door Size	2x2 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	02 hrs rating	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR

4. Smoke managements System			
• Basements	NA	Provided	NA
• Upper floors	Required	Provided	MR
5. Fire Extinguishers			
• Total numbers	As per IS 2190/1992	Provided	MR
• Types	CO ₂ & ABC	CO ₂ & ABC	MR
• IS marking	ISI marked	Provided	MR
6. First – Aid Hose Reels (Common with ECC)			
• Total numbers on each floor	Required	Provided	MR
• Length of hose reel hose	30 m	30 m	MR
• Nozzle diameter	5 mm	5 mm	MR
7. Automatic fire detection and alarming system			
• Type of detectors	Smoke & Heat	Provided	MR
• Location of Main Panel	Ground floor	Provided	MR
• Location of Repeater Panel	All floors	Provided	MR
• Alternate source of power	Required	Provided	MR
• Hooters' Location	Appropriate places	Near staircases	MR
8. MOEFA			
	Required	Provided	MR
9. Public Address System			
	Required	Provided	MR
10. Automatic Sprinkler System			
• Basements	NA	Provided	NA
• Upper Floor	Required	Provided	MR
• Sprinkler above false ceiling	Required	Provided	MR
11. Internal Hydrants (Common with ECC)			
• Size of riser/down- comer	150 mm	150 mm	MR
• Number of hydrants per floor	Required	Provided	MR
• Hose Box	Required	Provided	MR
12. Yard Hydrants			
• Total number of hydrants	13 Nos.	Provided	MR
• Hose Box	Required	Provided	MR
13. Pumping Arrangements (Common with ECC)			
• Ground Level			
• Discharge of main pump	2850 lpm(03 nos)	2850 lpm	MR
➤ Head of main pump	85 m	85 m	MR
➤ Number of main pumps	2 Nos	2 Nos	MR
➤ Jockey pump out put	280 lpm (4 Nos.)	280 lpm (4 Nos.)	MR
➤ Jockey pump head	85 m	85 m	MR
➤ Standby Pump out put	2850 lpm(2Nos)	Provided	MR
➤ Standby Pump Head	85 m	Provided	MR
➤ Auto Staring/Manual stopping	Required	Provided	MR
➤ Pump House Access	Required	Provided	MR
• Terrace level			
➤ Discharge of pump	N/A	N/A	N/A
➤ Head of the pump	N/A	N/A	N/A
➤ Power supply	N/A	N/A	N/A
➤ Auto starting of pump	N/A	N/A	N/A

4/4				
14.	Captive water Storage for fire fighting (Common with ECC)			
	• Under ground tank capacity	800,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room (Common with ECC)			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

1. Foodlink, F and B Holdings India Pvt. Ltd. Located at 2nd Floor ECC, Sector-25, Dwarka, Delhi..
2. As per letter/ plan submitted by the applicant the area of the restaurant is 538 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 299 (538/1.8=299) for whole restaurant.
4. The total seating capacity comes out be 299.

Signature of the Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW

Signature of the Inspecting Officer
Name: Udai Vir Singh
Designation: ADO/DWK

CFO(S2) 22/11/2021
Director

22/11/2021
2nd floor
fcc to +MTE