



C 28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2024 / School / WZ / 159

Dated 04/03/2024

FIRE SAFETY CERTIFICATE

Certified that the MC Primary Co-ed Pratibha School located at Nangli Poona, Delhi-110036 comprised of Ground and First floor owned/occupied by MC Primary Co-ed Pratibha School was issued FSC by this department vide letter No F6 /DFS/MS/2021/School/WZ/211 dated 11.03.2021. The premises was re-inspected by the officer concerned of this department on 22.02.2024 in the presence of Smt. Kavita (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ..04/03/2024.... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..04/03/2024. at New Delhi by

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, MC Primary Co-ed Pratibha School, Nangli Poona, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Electric Panel and electric meter under the staircase must be removed within a period of three months from the date of issuance of the Fire Safety Certificate. Failing to do so the Fire Safety Certificate will be null and void.

INSPECTION REPORT

1. Name & address of the building : MC Primary Co-ed Pratibha School, Nangli Poona, Delhi- 110036.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus First floor
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2021/School/WZ/211 dated 11/03/2021
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 22/02/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Smt. Kavita (Principal)
10. Year of Construction : 2010
11. Applicant's letter No. : E mail id dated 06/02/2024

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | DOE Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|----------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 6 m | Provided | MR |
| | • Gate width | 4.5 m | Directly Accessible | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floor | 1.50 m each | Provided | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1 m | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | Required | Naturally Ventilated | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 1 @ 300 sqm | Provided | MR |
| | • Types | ABC Type | Provided | MR |
| | • IS marking | Required | Provided | MR |
| 6. | First-Aid Hose Reels | | | |

4

pe

N. 2/

| | | | | |
|------------|---|----|----|----|
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | NA | NA | NA |
| | • Ground Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |

9/

| | | | | |
|-----|--|----------|----------|----|
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel found installed under the staircase which have to be removed to a safer place.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2021/School/WZ/211 dated 11/03/2021.

Dy (F&W)

23/2

28/2/21

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.