

C-100

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 177

Dated: 07/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the MRG Public School, run by St. Kabir Educational Society located at Pocket-B-5, Sector-3, Rohini, Delhi-110085, comprised of Basement + Ground + 04 upper floor owned/ occupied by St. Kabir Educational Society have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated 25.01.2024 in the presence of Mr. Vineet Kumar (Admin officer) and that the building/ premise is fit for occupancy Group B Educational with effect from 07/03/2024 for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2024 at New Delhi by

  
(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

**Copy to:**

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, MRG Public School, run by St. Kabir Educational Society located at Pocket-B-5, Sector-3, Rohini, Delhi-110085.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Six meter road will be restored on swimming pool side within six months and affected rooms shall not be used till road is restored.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

## INSPECTION REPORT

1. Name & address of the building	MRG Public School, run by St. Kabir Educational Society located at Pocket-B-5, Sector-3, Rohini, Delhi-110085.
2. Type of Occupancy	Educational
3. Type of Case	Additional /alternation ( <b>Basement + Ground + 04 upper floors</b> )
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/456 dated 07.07.2021 <b>Previous NOC- (Basement + Ground + 03 upper floors)</b>
5. Fire Safety directives letter No	F.6/DFS/MS/BP/2011/2426 dated 05.10.2011. F.6/DFS/MS/BP/2023/136 dated 23.03.2023.
6. Date of inspection	25.01.2024
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Vineet Kumar (Admin officer)
9. Year of Construction	2013 & 2023
10. Applicant's letter No.	Online e-mail dated 27.12.2024.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	5.0mtr	MR
	• Width of internal road	6.0m	Provided (except on corner of swimming pool it reduced by 1 meter)	MR (area on top floor affected by swimming pool shall not be used by school)
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>d. Number of staircases</b>			
	• Upper Floors	03	03	MR
	• Basements	03 + 01 ramp	03 + 01 ramp	MR
	<b>e. Width of staircases</b>			
	• Upper Floor	1.5m	1.5m	MR
	• Basements	1.5m	1.5m	MR
	<b>f. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	<b>d. No. of continuous staircases to terrace</b>	01	01	MR
	<b>e. Width of Corridor</b>	1.5m	Provided	MR
	<b>f. Door Size</b>	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	f) Fire check door	Required	Provided	MR
	g) Sealing of electrical shafts	Required	Provided	MR
	h) Fire Rating of shaft door	-NA-	-NA-	-NA-
	i) Water Curtain	-NA-	-NA-	-NA-
	j) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	c) Basements	31 /c per hour	Natural ventilated	MR
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	d) Total numbers	25nos.	30nos.	MR
	e) Types	ABC/CO2	ABC/CO2	MR
	f) IS marking	ISI marked	Yes	MR

<b>6. First-Aid Hose Reels</b>				
	d) Total numbers on each floor	03	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR
	f) Nozzle diameter	5m	Provided	MR
<b>7. Automatic fire detection and alarming system</b>				
	f) Type of detectors	Smoke/Heat	Provided	MR
	g) Location of Main Panel	Ground floor	Provided	MR
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
<b>8. MOEFA</b>		Required	Provided	MR
<b>9. Public Address System</b>		Required	Provided	MR
<b>10. Automatic Sprinkler System</b>				
	d) Basement	Required	Provided	MR
	e) Ground & Upper Floors	-NA-	-NA-	-NA-
	f) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11. Internal Hydrants</b>				
	d) Size of riser/down-comer	100mm	Provided	MR
	e) Number of hydrants per floor	03nos.	Provided	MR
	f) Hose Box	03nos.	Provided	MR
<b>12. Yard Hydrants</b>				
	c) Total number of hydrants	Required	02 nos. Provided	MR
	d) Hose Box	Required	02 nos. Provided	MR
<b>13. Pumping Arrangements</b>				
	• Ground Level			
	➤ Discharge of main Pump	2280lpm	2280lpm	MR
	➤ Head of Main pump	40m	40m	MR
	➤ Number of main pumps	01nos.	01nos.	MR
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby Pump out put	2280lpm	2280lpm	MR
	➤ Standby Pump Head	40m	40m	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14. Captive Water Storage for fire fighting</b>				
	• Underground tank capacity	1, 50,000ltr	1, 50,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000ltr	25,000ltr	MR
<b>15. Exit Signage.</b>		Required	Provided	MR
<b>16. Provision of Lifts.</b>				
	f) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	g) Pressurization of Lift lobby	-NA-	-NA-	-NA-

*Any*

N/43

	h) Communication In lift Car	Required	Provided	MR
	i) Fireman's Grounding Switch	Required	Provided	MR
	j) Lift Signage	-NA-	-NA-	-NA-
	Standby power supply	Required	Provided	MR
17.	Refuge Area.			
18.	c) Total Area	-NA-	-NA-	-NA-
	d) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	l) Detector System Panel	Required	Provided	MR
	g) Flow Switch Panel	-NA-	-NA-	-NA-
	h) PA System Panel	-NA-	-NA-	-NA-
	i) Battery backup	-NA-	-NA-	-NA-
	j) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Note :- applicant given undertaking that school will not use the affected area of top floor on swimming pool side.

*[Signature]*  
13/2/24

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

~~Dy. CFO (WZ)~~

*[Signature]*  
21/2/2024

528  
21/2/2024

~~CFO~~

Ask to close upper floor (additional floor) & renew up to 3rd floor only.

*[Signature]*  
22/2/2024

~~Dy CFO (WZ)~~

*[Signature]*  
22/2/24

528  
22/2/2024

~~ADO (Rohini)~~

DFA is amended as discussed for kind perusal and approval. Secs as fourth floor is already approved in building plans.  
*[Signature]*  
22/2/24

~~DCAO (WZ)~~

P.T.O