



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2024/WZ/184

Dated:- 07/03/2024

FIRE SAFETY CERTIFICATE

Certified that the **New Rana Public School** Located at Plot No. 479, Near Shishuwala Talab, Mundka, New Delhi-110041, comprised of Ground + 02 Upper Floors, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2021/73 dated 01/02/2021. The said premise was re-inspected by the officer concerned of this department on 28/02/2024 in the presence of Ms. Sushil Solanki (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 07/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 07/03/2024 at New Delhi by

(Atul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, New Rana Public School, Plot No. 479, Near Shishuwala Talab, Mundka, New Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **New Rana Public School Located at Plot No. 479, near Shishuwala Talab, Mundka, New Delhi-110041**
2. Type of Occupancy : Educational, (Ground + 02 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2021/73 Dated 01/02/2021
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 28/02/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Ms. Sushil Solanki (Principal)
9. Year of Construction : G+1 (2006) & G+2 (2015-16)
10. Applicant's letter No. : email dated 21/02/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV)/ as per FSC dated 01/02/2021		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	Accessible		Provided	MR
	• Gate width	Accessible		Provided	MR
	• Width of internal road	NA		NA	NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	01		02	MR
	• Basements	NA		NA	NA
	b. Width of staircases				
	• Upper floors	1.5 m	1.50 m x 1 & 1.10 m x 1		MR
	• Basements	NA		NA	NA
	c. Protection of exits				
	• Fire check door	NA		NA	NA
	• Pressurization	NA		NA	NA
	d. No of continuous staircase to terrace	01		Provided	MR
	e. Width Of Corridor	1.5 m		2.30 m	MR
	f. Door Size	1 m		1.0 m	MR
3.	Compartmentation			NA	
	• Fire check door	NA		NA	NA
	• Sealing of electrical shafts	NA		NA	NA
	• Fire Rating of shaft door	NA		NA	NA
	• Water Curtain	NA		NA	NA
	• Fire Dampers	NA		NA	NA
4.	Smoke managements System				
	• Basements	NA		NA	NA
	• Upper floors	NA		NA	NA
5.	Fire Extinguishers				
	• Total numbers	06 nos.		15 nos.	MR
	• Types	ABC & CO ₂		Provided	MR
	• ISI marking	ISI Marked		Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DPS/MS/School/WZ/2021/73 Dated 01/02/2021 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under the DPS Act 2007..

Accordingly DFA is put up for approval please.

Q11/H 11
29/02/24
Aman Kumar Lathar
ADO (JWP)

DCE/WZ

dy 01/02/24

*SB
13/02/24*

*c/o
u in room*

Director
A/10/24
Amr JWP

Sir, F.S. letter is put-up for your signature pl.

Director
A/10/24
N

Q11/H 11
06/05/24
AMN (JWP)