

FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No.F6/DFS/MS/SZ/2024/cc/18

Dated: 07/03/2024

FIRE SAFETY CERTIFICATE

Certified that building of Coaching center Located Plot No. 13, Sector-12B, Dwarka, New Delhi – 110075 in the building **comprised of Basement + Stilt + 04 Upper Floors** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 01/03/2024 in the presence of Mr. Ankit Singh (Admin) and found that the said building is fit for occupancy class "Educational" Group B (Coaching centre) with effect from 07/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2024 at New Delhi.



(Atul Garg)

Director

Delhi Fire Service.

Copy to:

- 1) Sh Ajay Gupta, Coaching center Located at Plot No. 13, Sector-12B, Dwarka, New Delhi – 110075.
- 2) The Executive Engineer (Bldg.) HQ, Muncipal Corporation of Delhi, 9th floor, Minto Road New Delhi – 110002.

Following fire safety directives must be adhered to:-

- 1) **All the exits passage leading to stairs shall be kept clear and free from lock & keys.**
- 2) All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3) Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4) The trained staff should be available round the clock.
- 5) Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6) The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7) The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8) Basement shall be used strictly as per building bye laws.
- 9) The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/2

INSPECTION REPORT


1. Name & address of the building: Coaching center Located at Plot No. 13, Sector-12B, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational ,(Basement + Stilt +4 UFs)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 01-03-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Ankit Singh (Admin)
9. Year of Construction : 2022-23
10. Applicant's letter No. : DFS Outdoor diary No. 12356, dated 29/01/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m (each)	Provided	MR
	• Basements	1.5m (each)	1.5 M	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge per hour	Provided	MR
	• Upper floors	12 a/c charge per hour	Natural ventilation	MR


14. Captive water Storage for fire fighting:			
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
	NA	NA	NA
	Required	Provided	MR
	NA	NA	NA
	15,000 L	Provided	MR
15	Exit Signage	Required	Provided
16. Provision of Lifts			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
	NA	NA	NA
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
17.	Standby power supply	Required	DG Set
18. Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ol style="list-style-type: none"> 1. Detector system panel 2. Flow Switch Panel 3. PA System Panel 4. Battery backup 5. Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.


 Sign of Inspecting Officer
 Name: Sh. Vedpal
 Designation: DO/SW


 Sign of Inspecting Officer
 Name: Udai vir Singh
 Designation: ADO/DWK

CFO (CSZ)

 5/31/2024

Director

 5/31/24


 ADO/DWK