

C-33

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024/CC/17

Dated: 07/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that building of Coaching center Located at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Plot No. 54, Block B, Sector-12, Dwarka, New Delhi – 110075 in the building **comprised of Basement + Ground + 03 Upper Floors** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 01/03/2024 in the presence of Mr. Tarun (Admin Officer) and found that the said building is fit for occupancy class "Educational" Group B (Coaching centre) with effect from 07/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2024 at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service  
01/03/24

Copy to:

1. Mr. Tarun (Admin Officer), Coaching center Located at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Plot No. 54, Block B, Sector-12, Dwarka, New Delhi – 110075.
2. The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9<sup>th</sup> floor, Minto Road New Delhi – 110002.

**Following fire safety directives must be adhered to:-**

1. All the exits passage leading to stairs & given at ground floor shall be kept clear and free from lock & keys.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: Coaching center Located at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Plot No. 54, Block B, Sector-12, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational, (Basement + Ground +3 UFs (Basement=Vacant, Ground floor= Bank & 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor= Coaching centre)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 01-03-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Tarun (Admin Officer)
9. Year of Construction : 2018
10. Applicant's letter No. : DFS Outdoor diary No. 12356, dated 29/01/2024

No. of Students=275

No. of class rooms=07

Plot area=2750sq.mtr

Covered area=504 sq.mtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m (each)	Provided	MR
	• Basements	1.5m (each)	1.5 M	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	Provided	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA


4.	Smoke managements System			
	• Basements	30 a/c charge per hour	Provided	MR
	• Upper floors	12 a/c charge per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	DCP, CO <sub>2</sub> & Water	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	Provided	NA
	• Alternate source of power	NA	Provided	NA
	• Hooters' Location	NA	Provided	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	30Mtr	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR


214


14.	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 L	Provided	MR
15.	Exit Signage	Required	Provided	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	1. Detector system panel	NA	NA	NA
	2. Flow Switch Panel	NA	NA	NA
	3. PA System Panel	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.

  
 Sign of Inspecting Officer  
 Name: Sh. Vedpal  
 Designation: DO/SW

  
 Sign of Inspecting Officer  
 Name: Udai vir Singh  
 Designation: ADO/DWK

  
 CFO (S2)

  
 Director

  
 ADO/DWK