

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2024/School/WZ/180

Dated: 07/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Vani Model School, A-5, Rajiv Nagar, Main Kanjhawala Road, Begum Pur, Delhi-110086, comprised of Ground + 01 upper floor owned/occupied by Vani Model School was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2021/89 dated 02.02.2021. The premises was re-inspected by the officer concerned of this department on 28.02.2024 in the presence of Mr. Amit Vashisht (Head Master) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from 07/03/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 07/03/2024 at New Delhi

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000  


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Vani Model School, A-5, Rajiv Nagar, Main Road, Begum Pur, Delhi-110086.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building	Vani Model School, A-5, Rajiv Nagar, Main Kanjhawala Road, Begum Pur, Delhi-110086.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal ( <b>Ground + 01 upper floor</b> )			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/89 dated 02.02.2021.			
5. Fire Safety directives letter No	Director of Education Cir. dated 1.03.20211.			
6. Date of inspection	28.02.2024			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Amit Vashisht (Head Master)			
9. Year of Construction	2004 & 2015			
10. Applicant's letter No.	Online e-mail dated 31.01.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Cir. DOE Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	3.0m	MR(Old case)
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	03nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m	2 x 1.5m & 1.0m	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	-NA-
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	06nos.	10nos.	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	a) Total numbers on each floor	-NA-	-NA-	-NA-
	b) Length of hose reel hose	-NA-	-NA-	-NA-
	c) Nozzle diameter	-NA-	-NA-	-NA-
7.	<b>Automatic fire detection and alarming system</b>			

my

H

	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	-NA-	-NA-	-NA-
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	<b>Standby power supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area.</b>			

a)	Total Area	-NA-	-NA-	-NA-
b)	Location	-NA-	-NA-	-NA-
<b>Fire Control Room</b>				
a)	Detector System Panel	-NA-	-NA-	-NA-
b)	Flow Switch Panel	-NA-	-NA-	-NA-
c)	PA System Panel	-NA-	-NA-	-NA-
d)	Battery backup	-NA-	-NA-	-NA-
e)	Building Floor Plans	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2021/89** dated **02.02.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name **Ajay Kumar Sharma**  
 Designation **ADO(Rohini)**

Dy. CFO (WZ)

*[Signature]*  
 01/03/2024

Sl. No. 612  
 Date: 13/03/2024

*[Signature]*  
 CFO  
 04/03/2024  
 Director  
*[Signature]*  
 01/03/24

*[Signature]*  
 Ajay Kumar

Fi letter is put up for kind  
 perusal and signature please

*[Signature]*  
 Director  
*[Signature]*

*[Signature]*  
 06/03/24