

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/Hospital/NDZ/2024/154

Dated: 11.03/2024

FIRE SAFETY CERTIFICATE

Certified that the EDP cell (D- Block) G.B. Pant Hospital at New Delhi. comprised of Basement + Gr. + 07 Upper floor, was earlier granted FSC by this department vide letter No. F6/DFS/MS/Hospital/2012/4776 dated 27/12/2012. Now, the premises was re-inspected by the officers concerned of this department on 02/03/24 in the presence of Sh. Amit Kumar JE (E) & Sh. Nand Lal Gupta AE and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises EDP cell (D- Block) is fit for occupancy class Institutional Building (Group C) with effect from 11.03/2024.... for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 11.03/2024....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD , Civic Centre , New Delhi
2. The Medical Superintendent, G.B. Pant Hospital, New Delhi.
3. The Assistant Engineer (E), HC-3, Health Maint. Elect. Division (C), PWD, GIPMER, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry

INSPECTION REPORT

1. Name & address of the building : EDP cell (D- Block)
G.B. Pant Hospital at New Delhi.
2. Type of occupancy : Institutional Building
Basement, Ground + 07 Upper floors
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/Hospital/2012/4776 dated 27/12/2012.
5. Fire safety directives No. : F6/DFS/MS/BP/Hospital/98/1777dated 10.09.98
6. Date of inspection:- 02/03/2024
7. Name of the inspecting officer : Sh. Rajinder Atwal DO/CD & Sh. Ravinder Singh ADO/CC
8. Name & designation of officer
From the building side : Mr. Amit kumar JE (E) & Sh. Nand Lal Gupta AE
9. Year of construction : 1998
10. Applicant's letter No : mail id rkbaehc3@gmail.com dated 23.02.2024.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6.0 mtr.	Provided	MR
	2) Gate width	05 mtr.	05 mtr.	MR
	3) Width of internal road	6 mtr.(03 sides)	Provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04 No.	04 No. ✓	MR
	2. Basements	03	03	MR
	B. Width of staircase			
	1. Upper floors (one ramp)	02 mtr & 1.35m.	02 mtr.&1.35m ✓	MR
	2. Basements	02 m & 1.35m	Provided	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	04	04	MR
	E. Width of corridor	2.4 mtr.	2.4 mtr. ✓	MR
	F. Door size	2.10 m	provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	Required	Provided	MR
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR

N/32

5.	Fire Extinguishers			
	1) Total numbers	Required	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 &	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	04	04 /	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	One at each floor	Provided	MR
	3) Location of repeater panel	Zone wise	Zone wise	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	At common area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	04	04 /	MR
	3) Hose box each floor	04	04 /	MR
12.	Yard Hydrants			
	1) Total number of hydrants	09	09 /	MR
	2) Hose box	09	09 /	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM /	MR
	b) Head of main pump	70 mtr.	70 mtr. /	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put (2 Nos.)	180 LPM	180 LPM /	MR
	e) Jockey pump head	70 mtr.	70 mtr. /	MR
	f) Stand by pump output	2850 LPM	2850 LPM /	MR
	g) Stand by pump head	70 mtr.	70 mtr. /	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 lpm	Provided	MR
	b) Head of pump	30 mtr	Provided	MR
	c) Power supply	Required	Provided	MR


N/33

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	40,000 Ltrs.	40,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.		Provided	MR
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:	Required CO2 flooding bank	Provided	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved we may renew the FSC issued vide letter no. F6/DFS/MS/Hospital/2012/4776 dated 27/12/2012, rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer


 Name: - Rajinder Atwal
 Designation: - DO (CD)

Signature of the Inspecting Officer


 Name: - Ravinder Singh
 Designation: - ADO (CC)

