

c/107

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SCHOOL/SZ/2024/197

Dated: 12/03/2024

FIRE SAFETY CERTIFICATE

Certified that the building of J M International School, Sector - 6, Dwarka, New Delhi - 110075 comprised of Basement, Ground +4 Upper Floors was issued FSC vide Letter No: F6/DFS/MS /School/SZ/2022 /836, dated-02/08/2022 (Issued to Basement + Ground + 3 Upper Floors). The premises was re inspected by the officer concerned of this department on 05/03/2024 in the presence of Sh. Yogesh Gupta (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service and that the premises is fit for occupancy class "Educational" Group B with effect from 12/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..12/03/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
12/03/24

Copy to:

- 1 The Principal, J M International School, Sector - 6, Dwarka, New Delhi .
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/30

INSPECTION REPORT

1. Name & address of the building: J M International School, Located at Sector - 6, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Basement + Ground +4 Upper Floors)
3. Type of Case : Addition/alteration
4. Details of previous NOC : F6/DFS/MS /School/SZ/2022 /836, dated- 02/08/2022 (Issued to Basement + Ground + 3 Upper Floors)
5. Fire Safety directives L. No. : F.6/DFS/MS/BP/2004/3123, dated 27/12/2004 & F.6/DFS/MS/BP/2022/430, dated 13/10/22
6. Date of inspection : 05-03-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side: Sh. Yogesh Gupta (Owner)
9. Year of Construction : 2005 & 2015 to -2023
10. Applicant's letter No. : Email, dated 02/03/2024

No. of Students=1480
No. of class rooms=42
Plot area=4411.93 sqmtr
Covered area=4322.78sqmtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	03 Nos.	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.5m	2X1.5m & 92 cm	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	30 a/c charge per hour	Provided	MR
	• Upper floors	12 a/c charge per, hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	Required. ABC & CO ₂ ISI marked	43 Nos.	MR
	• Types		DCP, CO ₂ & Water	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 Nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level	2280 lpm	Provided	MR
	• Discharge of main pump	88 M	Provided	MR
	➤ Head of main pump	01	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	40 m	Provided	MR
	➤ Jockey pump head	2280 lpm	Provided	MR
	➤ Standby Pump out put	88 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40Mtr	40Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

14.	Captive water Storage for fire fighting:			
	• Underground tank capacity	150000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000 L	25000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS /School/SZ/2022 /836, dated-02/08/2022 (Issued to Basement + Ground + 3 Upper Floors) renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Sh. Vedpal
 Signature of the Inspecting Officer
 Name: Sh. Vedpal
 Designation: DO/SW

Udai Vir Singh
 Signature of the Inspecting Officer
 Name: Udai Vir Singh
 Designation: ADO/DWK

CFO (S2)

7/9/2024
Director
7/9/24

Admission