



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Storage/SZ/2024/ 166

Dated: 14 / 03 / 2024

FIRE SAFETY CERTIFICATE

Certified that the **Central Warehouse & Store** situated at Plot No. 20, IGI Airport, New Delhi-110037, comprised of Ground Floor only, owned/occupied by Delhi International Airport Limited was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/Storage/SZ/410 dated 24/08/2021. The premise was re-inspected by the officers concerned of this department on 06/03/2024 in the presence of Sh. Rahul Sharma and observed that the said premise/building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "**Storage Building**" (Group 'H') with effect from 14/03/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/03/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/03/24

Copy to: -

1. Sh. P. Hrishikesan (Head ARFF), Delhi International Airport Limited, IGI Airport, New Delhi-110037
2. The C.E.O., DIAL, New Udaan Bhawan, Opp. Terminal-3, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from concerned authorities.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1.	Name & address of the building	Central Warehouse & Store at Plot No. 20, IGI Airport, New Delhi-110037		
2.	Type of Occupancy	Storage Building (Group-H)		
3.	Building Comprised of	Ground Floor only		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/SZ/2021/414 dated 27/08/2021		
6.	Fire Safety directives letter No.	F6/DFS/MS/BP/2019/421 dated 04/12/2021		
7.	Date of inspection	06/03/2024		
8.	Name of Inspecting Officer	Manoj Kumar Sharma (DO/SD) & Santosh Kumar ADO (S/J)		
9.	Name and designation of Officer from building side	Sh. Rahul Sharma		
10.	Year of Construction	2021		
11.	Applicant letter received through	Outdoor Diary No. 13527 dated 26/02/2024		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	20 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	6 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	Required	16 Nos	MR
	• Types	ABC/CO ₂	ABC/CO ₂ /WCO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Three	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke / Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	3 Nos	MR
	• Hose Box	Required	3 Nos	MR
12	Yard Hydrants			
	• Total number of hydrants	Required	2 Nos	MR
	• Hose Box	Required	2 Nos	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	1620 LPM	Provided	MR
	➤ Head of main pump	60m	Provided	MR
	➤ Number of main pumps	One	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	162 LPM	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	4,47,000 Ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/SZ/2021/414 dated 27/08/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

manish

Signature of the Inspecting Officer
Name: Manoj Kumar Sharma
Designation: DO (SD)

Shuman
07.03.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO(HQ)

Manish
11/31/2024

Director

Manish
11/3/24

ADP/SJ

Sir FT letter is put up for your sing. pl

Director
Manish
11/03/24

Shuman
13.03.24