



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No. F6/DFS/MS/2024/CNG/ 169

Dated 14 / 03 / 2024

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) located at Sanjay Gandhi Transport Nagar, Phase-II, Delhi-110042 comprised of Single Story Building owned/ occupied by Indraprastha Gas Limited was issued fire safety certificate by this department vide letter no. F6/DFS/MS/2021/CNG/223 dated 13.04.2021. The premises was inspected by the officers concerned of this department on 09.03.2024 in the presence of Sh. Keshav Saxena (Dy. Manager/IGL) and found that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy "CNG Filling Station Group 'J' with effect from 14/03/2024 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 14/03/2024 at New Delhi by

(Atul Garg)
Director
Ph:-011-23414000

Copy to :-

1. Sh. Ajay Khatri, GM (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot No-4, Community Centre, Sector-09, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at Sajnay Gandhi Transport Nagar, Ph-II, Delhi-110042.
2. Type of Occupancy : CNG Filling station Group 'J'
3. Composition of building : Ground floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021/CNG/223 Dated: 13.04.2021
6. Fire Safety directives letter No : Nil
7. Date of inspection : 09.03.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Keshav Saxena (Dy. Manager/IGL)
10. Year of Construction : --
11. Applicant's letter No. : IGL/F&S/2024/15/19/01 dated 27.02.2024

Plot Area- 1080m2

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	08m	30m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers.			
	• Total numbers	15nos	20nos	MR
	• Types	ABC & Co2	06 trolley- 75 kg. each, 10- DCP, 04-Co2	MR
	• ISI marking	Yes	Yes	MR

6	First-Aid Hose Reels.		
	• Total numbers on each floor	NA	NA
	• Length of hose reel hose	NA	NA
	• Nozzle diameter	NA	NA
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	Required	Provided
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants.		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A
	➤ Pump House Access		
	• Terrace level	NA	NA
	➤ Discharge of pump	NA	NA
	➤ Head of the pump	NA	NA
	➤ Power Supply	NA	NA
	➤ Auto Starting of pump	NA	NA
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA
	➤ Draw-off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	NA	NA
15	Exit Signage.	NA	NA

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & CO ₂ flooding system found provided		Provided MR

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/2021/CNG/223 dated 13.04.2021 under rule 37 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name: - C.L. Meena

Designation:- ADO/RN

Dy. Chief Fire Officer (WZ)

FO/.....712.....

dated.....11/3/2024.

[Handwritten signatures and dates]
 11/3
 11/3/2024
 Director
 11/03/24

[Handwritten signature]
 ADO/RN

conf - - - P.T.O.