



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2024/ 80

Dated: 13/03/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Domino's Pizza** situated at Shop No. 102-A, FF, Multi Level Car Parking-cum-Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-110023 building comprised of basement, ground & eight upper floors but the restaurant running at **First Floor only**, owned/occupied by M/s Jubilant Food Works Ltd. was issued fire safety certificate by this department vide letter No. F6/DFS/MS/2021/SZ/EH/70 dated 16/03/2021. The premise was re-inspected by the officer concerned of this department on 08/03/2024 in the presence of Mrs. Hema Sharma (Restaurant Manager) and observed that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "**Assembly Group D**" (Eating House at First Floor) up to 31/03/2027 in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 13/03/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
9/1/24

Copy to: -

1. The Joint Commissioner of Police (Lic.), First Floor, Police Station Defence Colony. New Delhi-110049 (w.r.t. MHA ID: 2024022302058 dated 27/02/2024)
2. Sh. Naveen Gupta M/s Jubilant Food Works Ltd, Shop No. 102-A, FF, Multi Level Car Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-23

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
	Name & Address of the Building	M/s Domino's Pizza India, Shop No. 102-A, FF, Multi Level Car Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-110023		
2	Type of Occupancy	Assembly "Group-D" (Eating House)		
3	Building Comprised of	Basement, Ground & 8 Upper Floors only but eating house is running at First Floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2021/SZ/EH/70 dated 16/03/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	08/03/2024		
8	Name of the Inspecting Officers	Santosh Kumar, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Hema Sharma (Restaurant Manager)		
10	Year of construction	2011 & 2014		
11	Applicant letter / MHA Portal ID No.	ID No. 2024022302058 dated 27/02/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	Access to Building. (MLCP FSC No. F6/DFS/MS/Mixed/SZ/2021/317 dated 12/07/2021)			
	• Road width	Eating House within Mall	As above	MR
	• Gate width		As above	MR
	• Width of internal road		As above	MR
2	Number, width, type & arrangement of exits.	Provided & Maintained by Mall Mgmt.		
	a) Number of Staircase			
	➤ Upper floors.	2nos	5nos	MR
	➤ Basement floor.	NA	NA	NA
	b) Width of Staircase	Provided & Maintained by Mall Mgmt.		
	➤ Upper floors	2m & 1.5m	1.5m x 2, 1.4m, 1.2m & 1.1m	MR (Old case)
	➤ Basement floor	NA	NA	NA
	c) Protection of exits	Provided & Maintained by Mall Mgmt.		
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	Required	Provided	MR
	f) Door size	2m & 1.5m	2m & 1.5m	MR
3	Compartmentation.	Provided & Maintained by Mall Mgmt.		
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Ground floor	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	ISI marked	05 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.	Provided & Maintained by Mall Mgmt.		
	• Total numbers on each floor.	One near Restt.	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System	Provided & Maintained by Mall Mgmt.		
	• Basement	NA	NA	NA
	• Ground floor.	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants.	Provided & Maintained by Mall Mgmt.		
	• Size of Riser/Down-comer	100mm	Provided	MR
	• Number of Hydrant per floor	NA	04 Nos	NA
	• Hose box.	NA	04 Nos	NA
12	Yard Hydrants.	Provided & Maintained by Mall Mgmt.		
	• Total number of hydrants.	NA	04 Nos	NA
	• Hose box.	NA	04 Nos	NA
13	Pumping arrangements.	Provided & Maintained by Mall Mgmt.		
	• Ground Level	Common firefighting system for entire Mall Bldg.		
	➤ Discharge of main pump.	NA	2850 LPM	NA
	➤ Head of main pump.	NA	70m	NA
	➤ Number of main pumps.	NA	Two	NA
	➤ Jockey Pump output.	NA	180 LPM x 2	NA
	➤ Jockey Pump head.	NA	70m	NA
	➤ Standby Pump output.	NA	2850 LPM	NA
	➤ Standby Pump head.	NA	70m	NA
	➤ Auto Starting/Manual Stopping.	NA	Provided	NA
	➤ Pump house access.	NA	Provided	NA
	• Terrace Level	Provided & Maintained by Mall Mgmt.		
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40m	40m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for firefighting. (Provided & Maintained by Mall Mgmt.)			
	• Underground tank capacity.	NA	1,50,000 Ltrs	NA
	➤ Draw-off connection.	NA	Provided	NA
	➤ Fire Service Inlet.	NA	Provided	NA
	➤ Access to tank.	NA	Provided	NA
	• Overhead tank capacity.	25,000 Ltrs	25,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	Provided	NA
	• Pressurization of lift lobby.	NA	Provided	NA
	• Communication in lift car.	NA	Provided	NA
	• Fireman's switch.	NA	Provided	NA
	• Lift signage.	NA	Provided	NA
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19	Fire Control Room.	Provided & Maintained by Mall Mgmt.		
	• Detector system panel.	NA	Provided	NA
	• Flow switch panel.	NA	N/A	NA
	• PA system panel.	NA	Provided	NA
	• Battery backup.	NA	Provided	NA
	• Building floor plan.	NA	Provided	NA
20	Special Fire Protection System for the Protection of special Risk, if any.	NA	Provided	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/2021/SZ/EH/70 dated 16/03/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA/FT is put up for approval and signature please.

S Kumar
09.03.24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

msl
9/3/24

C/S
11/3/2024
Director
11/3/24
ADP (S)

Sir,
F.T letter is put up for your sing. pl.

Director
12/3/24
msl

S Kumar
12-03-24

update
14/3/24
S