

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/CNG/2024/SZ/168

Dated: 14/03/2024

FIRE SAFETY CERTIFICATE

Certified that **CNG Dispensing Station** located at **Pushpa Bhawan, New Delhi** comprised of Single story building owned/occupied by M/s Indraprastha Gas Limited, was issued FSC by this department vide letter no. F6/MS/DFS/CNG/2021/SZ/242 Dated 28/04/2021. The premise was re-inspected by the officer concerned of this department on 06/03/2024 in the presence of Mr. Sunchit Sehrawat of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **class Hazardous (CNG Pump)** with effect from 14/03/2024 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 14/03/2024 at New Delhi by

(ATUL GANG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint C.P (Lic.) First Floor, PS Defence Colony, New Delhi 110049.
2. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/17

| INSPECTION REPORT | | | | |
|-------------------|---|--|--|----------------|
| 1 | Name & Address of the Building | CNG Dispensing station, Pushpa Bhawan, New Delhi | | |
| 2 | Type of Occupancy | Hazardous "Group -J (CNG Pump) | | |
| 3 | Building Comprised of | Ground floor only | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/MS/DFS/CNG/2021/SZ/242 Dated 28/04/2021 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 06-03-2024 | | |
| 8 | Name of the Inspecting Officers | Mr. Rajesh Kumar (ADO BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Sunchit Sehrawat | | |
| 10 | Year of construction | 2002 | | |
| 11 | Applicant letter No. | IGL/F&S/2024/15/69/1 Dated 19-02-2024 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC Requirement | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 09 mtr | Provided | MR |
| | • Gate width | -NA- | -NA- | -NA- |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type and arrangements of exits. | | | |
| | a. Number of Staircase | | | |
| | • Upper floors | -NA- | -NA- | -NA- |
| | • Basement floor | -NA- | -NA- | -NA- |
| | b. Width of Staircase | | | |
| | • Upper floors | -NA- | -NA- | -NA- |
| | • Basement floor | -NA- | -NA- | -NA- |
| | c. Protection of exits | | | |
| | • Fire check door | -NA- | -NA- | -NA- |
| | • Pressurization | -NA- | -NA- | -NA- |
| | d. No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e. Width of corridor | -NA- | -NA- | -NA- |
| | f. Door size | -NA- | -NA- | -NA- |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4 | Smoke Management system. | | | |
| | • Basement | -NA- | -NA- | -NA- |
| | • Upper floors | -NA- | -NA- | -NA- |
| 5 | Fire Extinguishers. | | | |
| | • Total numbers | Required | 24 Nos | MR |
| | • Types | ISI Marked | DCP/75 kg- 4, DCP/10kg - 15 & CO ₂ - 05 | MR |
| | • ISI Marking | | Provided | MR |
| 6 | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | -NA- | -NA- | -NA- |
| | • Length of hose-reel hose. | -NA- | -NA- | -NA- |
| | • Nozzle Diameter | -NA- | -NA- | -NA- |

| | | | | |
|-----|---|-------------|-----------------------------|------|
| 7 | Automatic Fire Detection and Alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | Gas & Flame | Provided in compressors | MR |
| | | Required | Ground floor | MR |
| | | -NA- | -NA- | -NA- |
| | | Required | Provided | MR |
| | | Required | Technician room | MR |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 14. | Captive water storage for fire-fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 15. | No Smoking signage | Required | Provided in Hindi & English | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17. | Standby Power Supply | NA | Provided (DG Set) | NA |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

11/19

| | | | | |
|-----|--|------|--|------|
| 19. | Fire Control Room. | | | |
| | • Detector System Panel. | -NA- | -NA- | -NA- |
| | • Flow Switch Panel. | -NA- | -NA- | -NA- |
| | • PA system Panel. | -NA- | -NA- | -NA- |
| | • Battery backup | -NA- | -NA- | -NA- |
| | • Building floor plan | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | NA | Co2 flooding system connected through detectors provided in each compressor unit | MR |

“No Smoking” Sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No F6/MS/DFS/CNG/2021/SZ/242 Dated 28/04/2021, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for perusal and signature please.

Signature of the Inspecting Officer
Name: Mr. Rajesh Kumar
Designation: ADO (BCP)

DO (SD)

11/3/24

11/3/24

11/3/24

As approved, F.T. letter is put up for your signature pl

13/3/24

13/3/24