

c/28

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/School/ 208

Dated: 18/03/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. boys Sr. Sec. School Located at, Naraina, New Delhi – 110008. comprised of Ground +1 Upper Floors was issued FSC vide Letter No. F.6/DFS/MS/School/SZ/2021/229, dated 16/03/2021 (Issued to Sarvodaya Bal Vidyalaya). The premises was re inspected by the officer concerned of this department on 06/03/2024 in the presence of Mr. Shiv Lal Meena (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 18/03/2024 for a period of three years.

Issued on 18/03/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service.
d/c
18/03/24

Copy to:

1. The Principal, Govt. boys Sr. Sec. School, Naraina, New Delhi – 110008.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/25

INSPECTION REPORT

1. Name & address of the building: Govt. boys Sr. Sec. School Located at, Naraina, New Delhi - 110008.
2. Type of Occupancy : Educational (Ground +01 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/SZ/2021/229, dated 16/03/2021
(Issued to Sarvodaya Bal Vidyalaya)
5. Fire Safety directives L. No. : Circular. 3298-3398 Dated 01/03/2011
6. Date of inspection : 06/03/2024
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer

from the building side : Mr. Shiv Lal Meena (Principal)

9. Year of Construction : 2014

10. Applicant's letter No.: GBSSS/N/287, dated 22/02/24

No. of Students=775

No. of class rooms=36

Plot area=3045sq.m

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17, N/18 & N/19	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a.			
	b. Number of staircases	03 Nos.	04 Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Width of staircases.	1.5 m	2x170cm, 1x156cm & 1x160cm	MR
	• Upper floors	NA	NA	NA
	• Basements			
	d. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No of continuous staircase to terrace	Required	Provided	MR
	f. Width Of Corridor	1.5 m	170 cm	MR
	g. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/SZ/2021/229, dated 16/03/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer
 Name *Uday Kumar Singh*
 Designation *AD Officer*

2/15/20
ah
15/03/21
CFO/RS2
15/31/2021
Director/RS2
15/03/21
mi