



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 206

Dated: 15 / 03 / 2024

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-Ed. Senior Secondary School** located at Laxmi Bai Nagar, New Delhi-110023 (ID: 1719101) comprised of Ground & two upper floors (1st Blk) & Ground Floor only (2nd Blk) has already been issued FSC vide letter No. F6/DFS/MS/School/SZ/2021/57 dated 21/01/2021. The premise was re-inspected by the officer concerned of this department on 11/03/2024 in the presence of Sh. Ranvir Singh (Vice Principal) and observed that school premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from 15 / 03 / 2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/03/2024 at New Delhi by


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

01/03/24

Copy to: -

1. The Principal, Govt. Co-Ed. Senior Secondary School, Laxmi Bai Nagar, New Delhi-23
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction. .
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Govt. Co-Ed. Senior Secondary School, Laxmi Bai Nagar, New Delhi-110023 (School ID-1719101)		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	G+2 (1 st Block) & GF only (2 nd Block)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/57 dt.21/01/2021		
6.	Fire Safety directives Letter No.	DOE Circular dated 01.03.2011		
7.	Date of inspection	11/03/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Sh. Ranvir Singh (Vice-Principal)		
10.	Year of Construction	1974		
11.	Applicant's letter No	Email dated 06/03/2024 ID principallbn@gmail.com		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ DOE Circular dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required N/A N/A	6m N/A N/A	MR N/A N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Required	2 Nos	MR
	<ul style="list-style-type: none"> • Upper floors • Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.50 / 0.75m NA	1.70m & 2m NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No of continuous staircase to terrace	Required	1	MR
	e. Width of Corridor	N/A	1.5m	N/A
	f. Door Size	1.00m	1.00m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	35 Nos ABC/W.CO ₂ ISI Marked	35 Nos ABC & CO ₂ Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 Nos 30m 5mm	Provided 30m 5mm	MR MR MR

KS

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	02 Nos	NA
	• Hose Box	NA	02 Nos	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr	12,000 Ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

810

✓

19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings communicated vide letter No. F.6/DFS/MS/School/SZ/2024/96 dated 01/03/2024 found complied.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/2021/57 dated 21/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
11.03.24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO(SD)

Murli
MS

CPD
12/31/2024

Director
17/03/24

ADO(SJ)

Sir,
F.T letter is put up for your sig. pl

Director
15/03/24
rm

S. Kumar
15/03/24